

- CURB CURB OR CURB AND GUTTER
- C/L CENTRELINE
- GAS GAS MAIN HYD - FIRE HYDRANT
- HYDV FIRE HYDRANT VALVE
- PWV PRIVATE WATER VALVE - PROPERTY LINE
- SL - STREETLIGHT
- SW - SIDEWALK
- SAN SANITARY SEWER
- STM STORM SEWER
- UTIITY BOX (HYDRO, TELECOMMUNICATIONS) UB
- UC - UTILITY CORRIDOR HYDRO, TELECOMM, GAS, SL)
- UTILITY POLE
- WATERMAIN

- THIS STANDARD THEY ARE TO BE INSTALLED AS CLOSE AS POSSIBLE TO THE PRESCRIBED LOCATION SUBJECT TO THE APPROVAL OF THE TRANSPORTATION AND WORKS DEPARTMENT OF THE CITY OF MISSISSAUGA
- 4. A 0.4m 0.6m CLEARANCE MUST BE MAINTAINED BETWEEN CABLES AND HYDRANTS
- 5. A 0.3m CLEARANCE MUST BE MAINTAINED BETWEEN WATERMAINS AND UTILITY POLES
- 6. CONCRETE TO BE IN ACCORDANCE WITH OPSS 351. REFER ALSO TO CITY STANDARD 2.02.03
- 7. ROAD WIDTH IS MEASURED FROM FACE OF CURB TO FACE OF CURB AS DEFINED ON OPSD STD. 600.040 CURB & GUTTER. PAVEMENT WIDTH IS MEASURED FROM EDGE OF PAVEMENT (EP) TO EDGE OF PAVEMENT (EP).
- 8. FOR LOCATION OF GAS MAIN WITHIN UTILITY CORRIDOR REFER TO STD. 2211.280



6 LANE ARTERIAL ROAD 23m ROAD ON 35m ROW

EFF. DATE		2002-01-01	SCALE	N.T.S.
REV.	10	2015-06-05	STANDARD No.	2211.130