



LEGEND

- EDGE OF PAVEMENT
- CATCH BASIN

CURB - CURB OR CURB AND GUTTER

- C/L CENTRELINE
- GAS GAS MAIN
- HYD FIRE HYDRANT
- HYDV FIRE HYDRANT VALVE
- PWV PRIVATE WATER VALVE
- PROPERTY LINE
- SL - STREETLIGHT
- SIDEWALK
- SAN SANITARY SEWER
- STM STORM SEWER
- UTIITY BOX (HYDRO, TELECOMMUNICATIONS) - UTILITY CORRIDOR (HYDRO, TELECOMM, GAS, SL) UC
- UTILITY POLE
- WATERMAIN

- HAVE A MINIMUM COVER OF 0.965m.
- 2. WATERMAIN TO HAVE A MINIMUM COVER OF 1.7m.
- 3. IF UTILITIES CANNOT BE INSTALLED ACCORDING TO THIS STANDARD THEY ARE TO BE INSTALLED AS CLOSE AS POSSIBLE TO THE PRESCRIBED LOCATION SUBJECT TO THE APPROVAL OF THE TRANSPORTATION AND WORKS DEPARTMENT OF THE CITY OF MISSISSAUGA
- 4. A 0.4m 0.6m CLEARANCE MUST BE MAINTAINED BETWEEN CABLES AND HYDRANTS.
- 5. A 0.3m CLEARANCE MUST BE MAINTAINED BETWEEN WATERMAINS AND UTILITY POLES.
- 6. CONCRETE TO BE IN ACCORDANCE WITH OPSS 351. REFER ALSO TO CITY STANDARD 2.02.03
- 7. ROAD WIDTH IS MEASURED FROM FACE OF CURB TO FACE OF CURB AS DEFINED ON OPSD STD. 600.040 CURB & GUTTER. PAVEMENT WIDTH IS MEASURED FROM EDGE OF PAVEMENT (EP) TO EDGE OF PAVEMENT (EP).
- 8. FOR LOCATION OF GAS MAIN WITHIN UTILITY CORRIDOR REFER TO STD, 2211,280



STANDARD 5 LANE RESIDENTIAL COLLECTOR ROAD 17m ROAD ON 30m ROW

EFF.DATE		2002-01-01	SCALE	N.T.S.
REV.	7	2015-06-05	STANDARD No.	2211.150