APPENDIX A

Water Demand Calculations



WATER DEMAND CALCULATIONS

POPULATION ESTIMATE		References
Apartment Building		
Region of Peel Population Densi	2.7 person/unit	Region of Peel Public Works Design,
Number of Units	920 units	Infrastructure Sanitary Sewer Design Criteria
Total Population	2484 persons	(March, 2017) - 2.1
Amenities		
Region of Peel Population Densi	50 person/hectare	Note: Includes Tower A&B and Amenity Area,
Amenity Area	0.53 hectares	both indoor and outdoor
Total Population	27 persons	
TYPICAL WATER DEMAND		
Average Consumption	280 L/cap * day	Region of Peel Public Works Design,
Equivalent Population	2511 persons	Specifications & Procedures Manual - Linear Infrastructure - Watermain Design Criteria (June, 2010) - 2.3 Table #1
Average Daily Demand	702986.2 L/day	
	8.14 L/s	
Maximum Day Factor	2.0	
Peak Hour Factor	3.0	
Maximum Daily Flow	1405972.4 L/day	
	16.27 L/s	
Peak Hour Flow	2108958.6 L/day	
	24.41 L/s	



WATER DEMAND CALCULATIONS

POPULATION ESTIMATE		References
Apartement Building		
Region of Peel Population Densi Number of Units Total Population	2.7 person/unit 452 units 1220 persons	Region of Peel Public Works Design, Specifications & Procedures Manual - Linear Infrastructure Sanitary Sewer Design Criteria
		(March, 2017) - 2.1
Amenities		
Region of Peel Population Densi	50 person/hectare	Region of Peel Public Works Design,
Amenity Area	0.21 hectares	Infrastructure Sanitary Sewer Design Criteria
Total Population	10 persons	(March, 2017) - 2.1
TYPICAL WATER DEMAND		
Average Consumption	280 L/cap * day	Region of Peel Public Works Design,
Equivalent Population	1231 persons	Specifications & Procedures Manual - Linear Infrastructure - Watermain Design Criteria (June, 2010) - 2.3 Table #1
Average Daily Demand	344604.4 L/day	
	3.99 L/s	
Maximum Day Factor	2.0	
Peak Hour Factor	3.0	
Maximum Daily Flow	689208.8 L/day	
	7.98 L/s	
Peak Hour Flow	1033813.2 L/day	
	11.97 L/s	



WATER DEMAND CALCULATIONS

POPULATION ESTIMATE		References
Apartment Building		
Region of Peel Population Densi	2.7 person/unit	Region of Peel Public Works Design,
Number of Units	570 units	Infrastructure Sanitary Sewer Design Criteria
Total Population	1539 persons	(March, 2017) - 2.1
Amenities		
Region of Peel Population Densi	50 person/hectare	Region of Peel Public Works Design,
Amenity Area	0.21 hectares	Specifications & Procedures Manual - Linear
Total Population	11 persons	(March, 2017) - 2.1
TYPICAL WATER DEMAND		
Average Consumption	280 L/cap * day	Region of Peel Public Works Design,
Equivalent Population	1550 persons	Specifications & Procedures Manual - Linear Infrastructure - Watermain Design Criteria (June, 2010) - 2.3 Table #1
Average Daily Demand	433869.8 L/day	
	5.02 L/s	
Maximum Day Factor	2.0	
Peak Hour Factor	3.0	
Maximum Daily Flow	867739.6 L/day	
	10.04 L/s	
Peak Hour Flow	1301609.4 L/day	
	15.06 L/s	



WATER DEMAND CALCULATIONS

POPULATION ESTIMATE		References
Apartment Building		
Region of Peel Population Densi	2.7 person/unit	Region of Peel Public Works Design,
Number of Units	600 units	Infrastructure Sanitary Sewer Design Criteria
Total Population	1620 persons	(March, 2017) - 2.1
Amenities		
Region of Peel Population Densi	50 person/hectare	Region of Peel Public Works Design,
Amenity Area	0.19 hectares	Infrastructure Sanitary Sewer Design Criteria
Total Population	10 persons	(March, 2017) - 2.1
TYPICAL WATER DEMAND		
Average Consumption	280 L/cap * day	Region of Peel Public Works Design,
Equivalent Population	1630 persons	Specifications & Procedures Manual - Linear Infrastructure - Watermain Design Criteria
Average Daily Demand	456296 4 L/day	(June, 2010) - 2.3 Table #1
	5.28 L/s	
Maximum Day Factor	2.0	
Peak Hour Factor	3.0	
	5.0	
Maximum Daily Flow	912592.8 L/day	
	10.56 L/s	
Peak Hour Flow	1368889.2 L/day	
	15.84 L/s	



WATER DEMAND CALCULATIONS 91 Eglinton Ave E. Proposed Residential Development - Total

SUMMARY OF WATER DEMAND

Phase	Number of Units	Population	Average Daily Demand (L/s)	Maximum Daily Flow (L/s)	Peak Hour Flow (L/s)
1	920	2484	8.14	16.27	24.41
2	452	1220	3.99	7.98	11.97
3	570	1539	5.02	10.04	15.06
4	600	1620	5.28	10.56	15.84
Total	2542	6863	22.43	44.86	67.28



Date: 2018.02.07 Designed By: NRS Checked By: NC Updated: 2019.05.31

		Part II - Guid	e for Deter	mination of Rea	quired Fire Flow		
I. An estimate of	fire flow req	uired for a giv	en area m	ay be determiı	ned by the form	iula:	
where F	= the requir	F = 220 * C	* sqrt A litres per m	ninute			
С	= coefficier		ne type of o for wood fro for ordinary for non-con for fire-resist	construction: ame construction construction (b nbustible constru- tive construction	n (structure esse rick or other mas uction (unprotec n (fully protected	ntially all combustible) onry walls, combustible floor and interior) ted metal structural components) frame, floors, roof)	
A	= The total 50 percer	floor area in s nt below grac	quare metr le) in the bi	res (including a uilding conside	II storeys, but ex red.	cluding basements at least	
Proposed Build	lings						
A = 280 C = (.6 sq.m.).8	ordinary co	onstruction		2070.07 sq.m 731.55 sq.m	area of largest floor 25% of each of the two immediately adjoinir	ng flo
Therefore F	= 9,3	16 L/min					
Fire f	low determir 30,00 30,00 25,00 25,00	ned above sh 20 L/min for w 20 L/min for o 20 L/min for no 20 L/min for fir	all not exce ood frame dinary con on-combus e-resistive c	eed: construction struction tible construct construction	ion		
2. Values obtaine be increased b	ed in No. 1 m by up to 25%	ay be reduce surcharge fo	ed by as mi occupance	uch as 25% for cies having a h	occupancies h igh fire hazard.	aving low contents fire hazard or may	
Non-Combustik mited Combustik Combustik	ble -25 ble -15 ble C	5% 5% 1% (No Chang	e)	Free Burning Rapid Burning	15% 25%		
Combustible				0%			

 Sprinklers - The value obtained in No. 2 above maybe reduced by up to 50% for complete automatic sprinkler protection. The credit for the system will be a maximum of 30% for an adequately designed system conforming to NFPA 13 and other NFPA sprinkler standards. 10% may be granted if the water supply is standard for both the system and fire departement hose lines required. Additional credit of up to 10% may be given for a fully supervised system.
 Building will have automatic sprinklers
 4,658 L/min reduction

Page 2

Water Supply for Public Fire Protection Fire Underwriters Survey

Part II - Guide for Determination of Required Fire Flow

4. Exposure - To the value obtained in No. 2, a percentage should be added for structures exposed within 45 metres by the fire area under consideration. The percentage shall depend upon the height, area, and construction of the building(s) being exposed, the separation, openings in the exposed building(s), the length and height of exposure, the provision of automatic sprinklers and/or outside sprinklers in the building(s) exposed, the occupancy of the exposed building(s) and the effect of hillside locations on the possible spread of fire.

Separation	Charge	Separation	Charge
0 to 3 m	25%	20.1 to 30 m	10%
3.1 to 10 m	20%	30.1 to 45 m	5%
10.1 to 20 m	15%		

Exposed buildings

Name		Distance		
North	Adjacent Dwelling	20.1 to 30 i	10%	931.57
West	Adjacent Commerc	10.1 to 20 i	15%	1397.36
				2 220 1

2,329 L/min Surcharge

Determine Required Fire Flow		
No.1 No.2	9,316 0 reduction	
No. 3	-4,658 reduction	
No. 4	2,329 surcharge	
Required Flow:	6,987 L/min	
Rounded to nearest 1000 L/min:	7,000 L/min or	116.7 L/s 1,849 USGPM
Required Volume		
kequied volume		
7,000 L/ × <u>120 m</u> 840,000 L	min in	

Required Duration	of Fire Flow	
Flow Required		Duration
L/min		(hours)
2,000 or less		1.0
	3,000	1.25
	4,000	1.5
	5,000	1.75
	6,000	2.0
	8,000	2.0
	10,000	2.0
	12,000	2.5
	14,000	3.0
	16,000	3.5
	18,000	4.0
	20,000	4.5
	22,000	5.0
	24,000	5.5
	26,000	6.0
	28,000	6.5
	30,000	7.0
	32,000	7.5
	34,000	8.0
	36,000	8.5
	38,000	9.0

	40,000 and over	9.5
_		· · · · · · · · · · · · · · · · · · ·



Date: 2018.02.07 Designed By: NRS Checked By: NC Updated: 2019.05.31

ater Supply	for Public Fire Protection
re Underwr	ters Survey Part II - Guide for Determination of Required Fire Flow
1. An estima	te of fire flow required for a given area may be determined by the formula:
where	F = 220 * C * sqrt A
where	F = the required fire flow in litres per minute
	C = coefficient related to the type of construction: = 1.5 for wood frame construction (structure essentially all combustible) = 1.0 for ordinary construction (brick or other masonry walls, combustible floor and interior) = 0.8 for non-combustible construction (unprotected metal structural components) = 0.6 for fire-resistive construction (fully protected frame, floors, roof)
	 A = The total floor area in square metres (including all storeys, but excluding basements at least 50 percent below grade) in the building considered.
Proposed	Buildings
A = C =	3471 sq.m.2314.16 sq.marea of largest floor0.8ordinary construction1157 sq.m25% of each of the two immediately adjoining floor
Theref	ore F = 10,369 L/min
	Fire flow determined above shall not exceed: 30,000 L/min for wood frame construction 30,000 L/min for ordinary construction 25,000 L/min for non-combustible construction 25,000 L/min for fire-resistive construction
2. Values ob be increa	tained in No. 1 may be reduced by as much as 25% for occupancies having low contents fire hazard or may sed by up to 25% surcharge for occupancies having a high fire hazard.
Non-Comb imited Comb Comb	ustible -25% Free Burning 15% ustible -15% Rapid Burning 25% ustible 0% (No Change)
Combusti	ole 0%
	0 L/min reduction
Nata - Els	

3. Sprinklers - The value obtained in No. 2 above maybe reduced by up to 50% for complete automatic sprinkler protection. The credit for the system will be a maximum of 30% for an adequately designed system conforming to NFPA 13 and other NFPA sprinkler standards. 10% may be granted if the water supply is standard for both the system and fire departement hose lines required. Additional credit of up to 10% may be given for a fully supervised system.

 Building will have automatic sprinklers

 5,184 L/min reduction

Page 2

Water Supply for Public Fire Protection Fire Underwriters Survey

Part II - Guide for Determination of Required Fire Flow

4. Exposure - To the value obtained in No. 2, a percentage should be added for structures exposed within 45 metres by the fire area under consideration. The percentage shall depend upon the height, area, and construction of the building(s) being exposed, the separation, openings in the exposed building(s), the length and height of exposure, the provision of automatic sprinklers and/or outside sprinklers in the building(s) exposed, the occupancy of the exposed building(s) and the effect of hillside locations on the possible spread of fire.

Separation	Charge	Separation	Charge
0 to 3 m	25%	20.1 to 30 m	10%
3.1 to 10 m	20%	30.1 to 45 m	5%
10.1 to 20 m	15%		

Exposed buildings

Name		Distance		
South	Adjacent Dwelling	20.1 to 30 i	10%	1036.88
West	Adjacent Commerc	20.1 to 30 i	10%	1036.88
East	Adjacent Dwelling	30.1 to 45 i	5%	518.44
				2 592

2,592 L/min Surcharge

Determine Required Fire Flow			Required Duratio
Determine Required file flow	No.1 10,369 No.2 0 reduction No.3 -5,184 reduction No.4 2,592 surcharge Required Flow: 7,777 L/min ded to nearest 1000 L/min: 8,000 L/min or 133.3 L/s 2,113 USC quired Volume x 120 min y60,000 L 120 min		I /min
No.1	10,369		2,000 or less
No. 2	0 reduction		
No. 3	-5,184 reduction		
No. 4	<u>2,592</u> surcharge		
Required Flow:	7,777 L/min		
Rounded to nearest 1000 L/min:	8,000 L/min or	133.3 L/s	
		2.113 USGPM	
Required Volume			
Required Volume			
Required Volume 8,000 L/	min		
Required Volume 8,000 L/ × <u>120 m</u>	min in		
Required Volume 8,000 L/ × <u>120 m</u> 960,000 L	min in		
Required Volume 8,000 L/ x <u>120 m</u> 960,000 L	min in		
Required Volume 8,000 L/ × <u>120 m</u> 960,000 L	min in		

equired Duration of I	Fire Flow	
ow Required		Duration
L/min		(hours)
,000 or less		1.0
	3,000	1.25
	4,000	1.5
	5,000	1.75
	6,000	2.0
	8,000	2.0
	10,000	2.0
	12,000	2.5
	14,000	3.0
	16,000	3.5
	18,000	4.0
	20,000	4.5
	22,000	5.0
	24,000	5.5
	26,000	6.0
	28,000	6.5
	30,000	7.0
	32,000	7.5
	34,000	8.0
	36,000	8.5

	38,000	9.0
40,000 and o	/er	9.5



Date: 2018.02.07 Designed By: NRS Checked By: NC Updated: 2019.05.31

		Part II - Guide for	Determination of Requ	ired Fire Flow	
1. An estimat	te of fire flow re	equired for a given ar	ea may be determine	d by the form	nula:
		F = 220 * C * sqrt	A		
where	F = the rea	uired fire flow in litres	per minute		
	C = COETTIC	$\begin{array}{rcl} \text{Ient related to the typ} \\ = & 1.5 & \text{for we} \\ = & 1.0 & \text{for or} \\ = & 0.8 & \text{for ne} \\ = & 0.6 & \text{for fire} \end{array}$	De of construction: bod frame construction dinary construction (bric on-combustible construction (f e-resistive construction (f	(structure esse k or other mase tion (unprotec fully protected	entially all combustible) onry walls, combustible floor and interior) ted metal structural components) frame, floors, roof)
	A = The toto 50 perc	al floor area in square cent below grade) in	e metres (including all s the building considere	storeys, but ex d.	cluding basements at least
Proposed	Buildings				
A = C =	2998 sq.m. 0.8	ordinary constru	ction	2228.67 sq.m 769 sq.m	area of largest floor 25% of each of the two immediately adjoining floo
Therefo	ore F = 9	,636 L/min			
ł	Fire flow detern 30 30 25 25	nined above shall no ,000 L/min for wood f ,000 L/min for ordinar ,000 L/min for non-co ,000 L/min for fire-resi	t exceed: rame construction y construction mbustible construction stive construction	٦	
2. Values ob be increas	tained in No. 1 sed by up to 25	may be reduced by 5% surcharge for occu	as much as 25% for or upancies having a hig	ccupancies h h fire hazard.	aving low contents fire hazard or may
Non-Comb imited Comb Comb	ustible - ustible - ustible	25% 15% 0% (No Change)	Free Burning Rapid Burning	15% 25%	
Combustik	ble		0%		
		0 I/min reduction			

3. Sprinklers - The value obtained in No. 2 above maybe reduced by up to 50% for complete automatic sprinkler protection. The credit for the system will be a maximum of 30% for an adequately designed system conforming to NFPA 13 and other NFPA sprinkler standards. 10% may be granted if the water supply is standard for both the system and fire departement hose lines required. Additional credit of up to 10% may be given for a fully supervised system. Building will have automatic sprinklers 4,818 L/min reduction

Page 2

Water Supply for Public Fire Protection Fire Underwriters Survey

Part II - Guide for Determination of Required Fire Flow

4. Exposure - To the value obtained in No. 2, a percentage should be added for structures exposed within 45 metres by the fire area under consideration. The percentage shall depend upon the height, area, and construction of the building(s) being exposed, the separation, openings in the exposed building(s), the length and height of exposure, the provision of automatic sprinklers and/or outside sprinklers in the building(s) exposed, the occupancy of the exposed building(s) and the effect of hillside locations on the possible spread of fire.

Separation	Charge	Separation	Charge
0 to 3 m	25%	20.1 to 30 m	10%
3.1 to 10 m	20%	30.1 to 45 m	5%
10.1 to 20 m	15%		

Exposed buildings

Name	Distance	
North	Adjacent Dwelling 30.1 to 4515%	481.81
South	Adjacent Dwelling 30.1 to 4515%	481.81
West	Adjacent Commer 30.1 to 4515%	481.81
East	Adjacent Commer(20.1 to 30 1 10%	963.61
		2,409 L/min Surcharge

Determine Required Fire Flow		
No.1	9,636	
No. 2	0 reduction	
No. 3	-4,818 reduction	
No. 4	2.409 surcharae	
	<u></u>	
Required Flow:	7,227 L/min	
Rounded to nearest 1000 L/min:	7,000 L/min or	116.7 L/s
		1,849 USGPM
Required Volume		
7,000 L/1	min	
×120 mi	in	
840,000 L		

Required Duration of	Fire Flow	
Flow Required		Duration
L/min		(hours)
2,000 or less		1.0
	3,000	1.25
	4,000	1.5
	5,000	1.75
	6,000	2.0
	8,000	2.0
	10,000	2.0
	12,000	2.5
	14,000	3.0
	16,000	3.5
	18,000	4.0
	20,000	4.5
	22,000	5.0
	24,000	5.5
	26,000	6.0
	28,000	6.5
	30,000	7.0
	32,000	7.5
	34,000	8.0

		36,000	8.5
		38,000	9.0
	40,000 and over		9.5



Date: 2018.02.07 Designed By: NRS Checked By: NC Updated: 2019.05.31

Water Supply Fire Underwrit	for Public Fi ers Survey	re Protection Part II - Guide for	Determination of Rec	uired Fire Flow		
1. An estimate	e of fire flow r	equired for a given c	irea may be determin	ed by the form	nula:	
		F = 220 * C * sqr	† A			
where	F = the rec	quired fire flow in litres	s per minute			
	C = coeffic	cient related to the ty = 1.5 for w = 1.0 for o = 0.8 for n = 0.6 for fi	pe of construction: vood frame construction rdinary construction (br on-combustible constru re-resistive construction	n (structure esse ick or other mas uction (unprotec (fully protected	entially all combustible) onry walls, combustible floor and interior) ted metal structural components) frame, floors, roof)	
	A = The tot 50 per	al floor area in squar cent below grade) in	e metres (including al the building consider	l storeys, but ex red.	cluding basements at least	
Proposed B	uildings					
A = 4 C =	4384.4 sq.m. 0.8	ordinary constru	uction	3056.61 sq.m 1327.83 sq.m	area of largest floor 25% of each of the two immediately adjoining f	loor
Therefo	reF= 11	l,654 L/min				
F	ire flow deter	mined above shall no	ot exceed:			
	30),000 L/min for wood	frame construction			
	30),000 L/min for ordinc	iry construction	22		
	25	5,000 L/min for fire-res	sistive construction			
2. Values obt	ained in No. 1 ed by up to 2	may be reduced by 5% surcharge for occ	y as much as 25% for o cupancies having a hi	occupancies h gh fire hazard.	aving low contents fire hazard or may	
Non-Combu	ustible	-25%	Free Burning	15%		
Limited Combu Combu	ustible ustible	-15% 0% (No Change)	Rapid Burning	25%		
Combustib	le		0%			
	11	0 L/min reductior ,654 L/min	1			
Note: Flow	determined	hall not be less than	2 000 L /min			

3. Sprinklers - The value obtained in No. 2 above maybe reduced by up to 50% for complete automatic sprinkler protection. The credit for the system will be a maximum of 30% for an adequately designed system conforming to NFPA 13 and other NFPA sprinkler standards. 10% may be granted if the water supply is standard for both the system and fire departement hose lines required. Additional credit of up to 10% may be given for a fully supervised system. Building will have automatic sprinklers 5,827 L/min reduction

Page 2

Water Supply for Public Fire Protection Fire Underwriters Survey

Part II - Guide for Determination of Required Fire Flow

4. Exposure - To the value obtained in No. 2, a percentage should be added for structures exposed within 45 metres by the fire area under consideration. The percentage shall depend upon the height, area, and construction of the building(s) being exposed, the separation, openings in the exposed building(s), the length and height of exposure, the provision of automatic sprinklers and/or outside sprinklers in the building(s) exposed, the occupancy of the exposed building(s) and the effect of hillside locations on the possible spread of fire.

Separation	Charge	Separation	Charge
0 to 3 m	25%	20.1 to 30 m	10%
3.1 to 10 m	20%	30.1 to 45 m	5%
10.1 to 20 m	15%		

Exposed buildings

Name	-	Distance		
North	Adjacent Dwelling	20.1 to 30 i	10%	1165.39
East	Adjacent Dwelling	20.1 to 30 i	10%	1165.39
West	Adjacent Dwelling	30.1 to 45 i	5%	582.69
				2 913

2,913 L/min Surcharge

No. 4	-5,827 reduction 2 913 surcharge	
Required Flow: Rounded to nearest 1000 L/min:	8,740 L/min 9,000 L/min or	150.0 L/s 2,378 USGPM
Required Volume		
9,000 L/n × <u>120 mi</u> ı 1,080,000 L	nin n	

Flow	
	Duration
	(hours)
	1.0
3,000	1.25
4,000	1.5
5,000	1.75
6,000	2.0
8,000	2.0
10,000	2.0
12,000	2.5
14,000	3.0
16,000	3.5
18,000	4.0
20,000	4.5
22,000	5.0
24.000	5.5
26.000	6.0
28.000	6.5
30.000	7.0
32.000	7.5
34,000	8.0
36.000	8.5
	Flow 3,000 4,000 5,000 8,000 12,000 12,000 14,000 16,000 18,000 22,000 22,000 24,000 24,000 26,000 28,000 30,000 32,000 34,000

	38,000	9.0
40,000 and o	/er	9.5



Consulting Engineers

Date: 2018.02.07

Designed By: NRS Checked By: NC Updated: 2019.05.31

Water Supply for Public Fire Protection Fire Underwriters Survey Results Summary

Phase	Number of	Floor Area	Demo	and Flow	Duration
Fliase	Units	(m³)	(L/s)	(USGPM)	Duranon
1	920	2802	116.7	1849	2.00
2	452	3471	133.3	2113	2.00
3	570	2998	116.7	1849	2.00
4	600	4384	150.0	2378	2.00

1000 - 2 Bloor Street East Toronto, Ontario, M4W 1A8 TEL **416.966.0220**

10154 - 108 Street Edmonton, Alberta T5J 1L3 TEL **780.429.1580**

300 – 134 11th Avenue SE Calgary, Alberta, T2G OX5 TEL 403.245.5501 406 - 611 Alexander Street Vancouver, BC, V6A 1E1 TEL 604.255.1169

July 05, 2018

DIALOG

Mr. Nick Constantin, P. Eng. Crosier and Associates Consulting Engineers 2800 High Point Drive, Suite 100 Milton, ON L9T 6P4 (905) 875-0026 Project No. 11153T

Re: Proposed Residential Development - 91 Eglinton Avenue E, Mississauga ON

Dear Nick:

This Letter serves to confirm that all buildings within this proposed development will be of noncombustible construction and sprinklered. All floor assemblies and vertical openings will have a minimum fire-resistance rating of 2 hours as per Ontario Building Code 3.2.2.42.

We trust that this letter is sufficient to address Development Engineering's request to confirm the type of building construction.

Sincerely,

minon Do

Simon Ko Principal

APPENDIX B

Sanitary Sewer Demand Calculations



Revised: 2019.05.31

SANITARY CALCULATIONS 91 Eglinton Ave E. Proposed Residential Development - Phase 1

POPULATION ESTIMATE			References
Apartment Building			
Region of Peel Population Densi	ty 2.7 person/uni	t	Region of Peel Public Works Design,
Number of Units	920 units		I inear Infrastructure Sanitary Sewer
Total Population	2484 persons		Design Criteria (March, 2017) - 2.1
Total Developed Area	1.0 ha		
Amenity Area			
Region of Peel Population Densi	ty 50 person/he	ctare	Region of Peel Public Works Design,
Amenity Area	2.48 hectares		Linear Infrastructure Sanitary Sewer
Total Population	124 persons		Design Criteria (March, 2017) - 2.1
SANITARY DESIGN FLOW - REG	GION OF PEEL METHOD		
Average daily demand	302.8 L/person *	day	Region of Peel Public Works Design,
Equivalent Population	2608 persons		Specifications & Procedures Manual Linear Infrastructure - Sanitary Sewer
Harmon Peaking Factor (M) M = 1+(14/(4+p^0.5))	3.51		Design Criteria (March, 2017) - 2.2
Average Daily Flow	789673 63 L/day		
	9.14 L/s	l i i i i i i i i i i i i i i i i i i i	
Peak Flow	2772329.7 L/day		
	32.09 L/s		
Infiltration	0.0002 cms/ha		Region of Peel Public Works Design,
	0.000208 cms		Specifications & Procedures Manual
	0.21 L/s		Design Criteria (March, 2017) - 2.3
Total Sanitary Flow	32.30 L/s		



SANITARY CALCULATIONS

91 Eglinton Ave E. Proposed Residential Development - Phase 2

POPULATION ESTIMATE References **Apartment Building** Region of Peel Population Density Region of Peel Public Works Design, 2.7 person/unit Specifications & Procedures Manual -Number of Units 452 units Linear Infrastructure Sanitary Sewer Total Population 1220 persons Design Criteria (March, 2017) - 2.1 0.6 ha Total Developed Area **Amenity Area** Region of Peel Public Works Design, Region of Peel Population Density 50 person/hectare Specifications & Procedures Manual -Amenity Area 0.21 hectares Linear Infrastructure Sanitary Sewer Total Population 10 persons Design Criteria (March, 2017) - 2.1 SANITARY DESIGN FLOW - REGION OF PEEL METHOD Region of Peel Public Works Design, Average daily demand 302.8 L/person * day Specifications & Procedures Manual -Equivalent Population 1231 persons Linear Infrastructure - Sanitary Sewer Design Criteria (March, 2017) - 2.2 Harmon Peaking Factor (M) 3.74 $M = 1 + (14/(4 + p^{0.5}))$ **Average Daily Flow** 372665.04 L/day 4.31 L/s **Peak Flow** 1394721.8 L/day 16.14 L/s Region of Peel Public Works Design, Infiltration 0.0002 cms/ha Specifications & Procedures Manual -0.000116 cms Linear Infrastructure - Sanitary Sewer 0.12 L/s Design Criteria (March, 2017) - 2.3 **Total Sanitary Flow** 16.26 L/s



Revised: 2019.05.31 SANITARY CALCULATIONS

91 Eglinton Ave E. Proposed Residential Development - Phase 3

POPULATION ESTIMATE References **Apartment Building** Region of Peel Population Density Region of Peel Public Works Design, 2.7 person/unit Specifications & Procedures Manual -Number of Units 570 units Linear Infrastructure Sanitary Sewer Total Population 1539 persons Design Criteria (March, 2017) - 2.1 0.7 ha Total Developed Area **Amenity Area** Region of Peel Public Works Design, Region of Peel Population Density 50 person/hectare Specifications & Procedures Manual -Amenity Area 0.21 hectares Linear Infrastructure Sanitary Sewer Total Population 11 persons Design Criteria (March, 2017) - 2.1 SANITARY DESIGN FLOW - REGION OF PEEL METHOD Region of Peel Public Works Design, Average daily demand 302.8 L/person * day Specifications & Procedures Manual -Equivalent Population 1550 persons Linear Infrastructure - Sanitary Sewer Design Criteria (March, 2017) - 2.2 Harmon Peaking Factor (M) 3.67 $M = 1 + (14/(4 + p^{0.5}))$ **Average Daily Flow** 469199.2 L/day 5.43 L/s **Peak Flow** 1722649.8 L/day 19.94 L/s Region of Peel Public Works Design, Infiltration 0.0002 cms/ha Specifications & Procedures Manual -0.0001419 cms Linear Infrastructure - Sanitary Sewer 0.14 L/s Design Criteria (March, 2017) - 2.3 **Total Sanitary Flow** 20.08 L/s



Revised: 2019.05.31

SANITARY CALCULATIONS

91 Eglinton Ave E. Proposed Residential Development - Phase 4

POPULATION ESTIMATE References **Apartment Building** Region of Peel Population Density Region of Peel Public Works Design, 2.7 person/unit Specifications & Procedures Manual -Number of Units 600 units Linear Infrastructure Sanitary Sewer Total Population 1620 persons Design Criteria (March, 2017) - 2.1 0.8 ha Total Developed Area **Amenity Area** Region of Peel Public Works Design, Region of Peel Population Density 50 person/hectare Specifications & Procedures Manual -Amenity Area 0.19 hectares Linear Infrastructure Sanitary Sewer Total Population 10 persons Design Criteria (March, 2017) - 2.1 SANITARY DESIGN FLOW - REGION OF PEEL METHOD Region of Peel Public Works Design, Average daily demand 302.8 L/person * day Specifications & Procedures Manual -Equivalent Population 1630 persons Linear Infrastructure - Sanitary Sewer Design Criteria (March, 2017) - 2.2 Harmon Peaking Factor (M) 3.66 $M = 1 + (14/(4 + p^{0.5}))$ **Average Daily Flow** 493451.96 L/day 5.71 L/s **Peak Flow** 1803635.9 L/day 20.88 L/s Region of Peel Public Works Design, Infiltration 0.0002 cms/ha Specifications & Procedures Manual -0.0001616 cms Linear Infrastructure - Sanitary Sewer 0.16 L/s Design Criteria (March, 2017) - 2.3 **Total Sanitary Flow** 21.04 L/s



SANITARY CALCULATIONS 91 Eglinton Ave E. Proposed Residential Development - Total

SUMMARY OF SANITARY DESIGN FLOWS

Phase	Number of Units	Population	Harmon Peaking Factor	Average Daily Flow (L/s)	Peak Flow (L/s)	Infiltration (L/s)	Total Sanitary Flow (L/s)
1	920	2484	3.51	9.14	32.09	0.21	32.30
2	452	1220	3.74	4.31	16.14	0.12	16.26
3	570	1539	3.67	5.43	19.94	0.14	20.08
4	600	1620	3.66	5.71	20.88	0.16	21.04
Total	2542	6863	-	24.59	89.04	0.16	89.67

Nicole Segal

From:	Mitra, Soyuz <soyuz.mitra@peelregion.ca></soyuz.mitra@peelregion.ca>
Sent:	Monday, July 9, 2018 2:54 PM
То:	Nicole Segal
Cc:	Miriam Polga; Nick Constantin
Subject:	FW: 91 Eglinton Ave E Internal Sanitary Upsizing (CFCA#1525-4876)
Follow Up Flag:	Follow up
Flag Status:	Completed

Hi Nicole,

Please see below the response from the wastewater team about your question. Let me know if you have any further questions.

Thanks

Soyuz Mitra P.Eng Project Manager, EA and Studies, Program Planning & Compliance

The Region of Peel

10 Peel Centre Drive, Suite A, 4th Floor, Brampton, L6T4B9 Tel. 905-791-7800 X 4550 Mob. 416-844-7543 Fax 905-791-1442 <u>Soyuz.mitra@peelregion.ca</u>



From: Motamedi, Kolsoom
Sent: July 9, 2018 2:35 PM
To: Mitra, Soyuz
Cc: Zhu, Hong; Polga, Miriam
Subject: RE: 91 Eglinton Ave E Internal Sanitary Upsizing (CFCA#1525-4876)

Hi,

The proposed sewers on the future Thornwood Drive from manhole number MH4 to MH5 and MH6 (below sketch) is 375 mm with a minimum slope of 0.5%.

The proposed sewer from the manhole number MH6 to the existing manhole on Eglinton Ave. East is 375 mm with 0.8 % slope.

Thanks and Regards,

Kolsoom Motamedi,



From: Nicole Segal [mailto:nsegal@cfcrozier.ca] **Sent:** July 6, 2018 12:06 PM **To:** Polga, Miriam

Cc: Nick Constantin **Subject:** 91 Eglinton Ave E Internal Sanitary Upsizing (CFCA#1525-4876)

Good morning Miriam,

Nick Constantin and Nick Mocan from our office met with yourself and other Region staff on June 11, 2018 to discuss the water and wastewater servicing for 91 Eglinton Avenue East, Mississauga. During that meeting the Region indicated that upsizing of the proposed sanitary sewers on Thornwood Drive will be required to accommodate Summitview flows (Block 46).

Based on the attached Urban Tech schematic design can you please confirm the sewers which require upsizing, the required size, and confirm if the existing slopes shown are adequate?

Thank you, we appreciate your time! Regards,

| **NICOLE SEGAL** M.M.Sc., E.I.T. | C.F. CROZIER & ASSOCIATES | 2800 High Point Drive, Suite 100 | Milton, ON L9T 6P4 | <u>cfcrozier.ca</u> | <u>nsegal@cfcrozier.ca</u> | tel 905 875 0026



Land development engineering, from the ground up. Water Resources-Transportation-Structural-Mechanical-Electrical-Building Science

This communication is intended solely for the attention and use of the named recipients and contains information that is privileged and confidential. If you are not the intended recipient, or the person responsible for delivering this information to the intended recipient, please notify us immediately by telephone. If you have received this information in error, please be notified that you are not authorized to read, copy, distribute, use or retain this message or any part of it.

APPENDIX C

Stormwater Management Calculations



Modified Rational Method - Summary

Туре	Area (ha)	Pre-Development RC	Post-Development Rc	Storage Required (m³)	Required Water Balance Storage (m ³)
Phase 1	1.04			576	39
Phase 2	0.58	0.3	0.0	331	22
Phase 3	0.71	0.5	0.7	387	27
Phase 4	1.17			637	44
	3.51				



Project: 91 Eglinton Avenue East Project No.: 1525-4876 Date: 2019-05-31 Designed By: NRS Checked By: NC

Modified Rational Method - Input Data						
Storm Data: City of Mississauga					References	
Time of Concentration:		1.5	min =	= 0.25 hours		
			=	= 900 sec		
Return Period	Α	В	С	i	City of Mississauga	
				mm/hr	Development	
2 yr	610	4.6	0.78	59.89	(2.01.01.01)- September	
5 yr	820	4.6	0.78	80.51	2016	
10 yr	1010	4.6	0.78	99.17		
25 yr	1160	4.6	0.78	113.89		
50 yr	1300	4.7	0.78	127.13		
100 yr	1450	4.9	0.78	140.69		
				<u> </u>		
Pre-Developm	ent	•		-		
land lise	Area	Area		Runoff in 100-		
	(ha)	(m²)	С	year storm		
Phase 1	1.04	10443	0.3	0.38	Assume entire area is grass	
Phase 2	0.58	5800	0.3	0.38	_	
Phase 3	0./1	/094	0.3	0.38	_	
Phase 4	2.51	25042	0.3	0.38	-	
lofdi Sife	3.51	35063			-	
Post- Developm	nent]			
	Area	Area		Runoff in 100-	Runoff coefficient based	
Lana use		0	-			
	(ha)	(m²)	C	year storm	on high-fise residential	
Phase 1: Catchment 201	(ha) 0.96	(m²) 9600	C 0.9	1.00	criteria from City of Mississauga Development	
Phase 1: Catchment 201 Catchment UC13	(ha) 0.96 0.05	(m²) 9600 543	0.9 0.5	year storm 1.00 0.63	criteria from City of Mississauga Development Requirements Manual	
Phase 1: Catchment 201 Catchment UC13 Catchment UC19	(ha) 0.96 0.05 0.03	(m ²) 9600 543 300	C 0.9 0.5 0.5	year storm 1.00 0.63 0.63	criteria from City of Mississauga Development Requirements Manual (2.01.01.01) - September	
Phase 1: Catchment 201 Catchment UC13 Catchment UC19 Phase 1 Total	(ha) 0.96 0.05 0.03 1.04	(m ²) 9600 543 300 10443	C 0.9 0.5 0.5 	year storm 1.00 0.63 0.63	criteria from City of Mississauga Development Requirements Manual (2.01.01.01) - September 2016	
Phase 1: Catchment 201 Catchment UC13 Catchment UC19 Phase 1 Total Phase 2: Catchment 202	(ha) 0.96 0.05 0.03 1.04 0.50	(m ²) 9600 543 300 10443 5000	C 0.9 0.5 0.5 	year storm 1.00 0.63 0.63 1.00	criteria from City of Mississauga Development Requirements Manual (2.01.01.01) - September 2016	
Phase 1: Catchment 201 Catchment UC13 Catchment UC19 Phase 1 Total Phase 2: Catchment 202 Catchment UC15	(ha) 0.96 0.05 0.03 1.04 0.50 0.03	(m ²) 9600 543 300 10443 5000 300	C 0.9 0.5 0.5 0.9 0.5	year storm 1.00 0.63 0.63 1.00 0.63	criteria from City of Mississauga Development Requirements Manual (2.01.01.01) - September 2016	
Phase 1: Catchment 201 Catchment UC13 Catchment UC19 Phase 1 Total Phase 2: Catchment 202 Catchment UC15 Catchment UC16	(ha) 0.96 0.05 0.03 1.04 0.50 0.03 0.05	(m ²) 9600 543 300 10443 5000 300 500	C 0.9 0.5 0.9 0.5 0.5	year storm 1.00 0.63 1.00 0.63 1.00 0.63 0.63	criteria from City of Mississauga Development Requirements Manual (2.01.01.01) - September 2016	
Phase 1: Catchment 201 Catchment UC13 Catchment UC19 Phase 1 Total Phase 2: Catchment 202 Catchment UC15 Catchment UC16 Phase 2 Total	(ha) 0.96 0.05 0.03 1.04 0.50 0.03 0.03 0.05 0.58 0.48	(m ²) 9600 543 300 10443 5000 300 500 5800 (200	C 0.9 0.5 0.5 0.9 0.5 0.5 	year storm 1.00 0.63 0.63 1.00 0.63 1.00 0.63 1.00 0.63 0.63 1.00 0.63	criteria from City of Mississauga Development Requirements Manual (2.01.01.01) - September 2016	
Phase 1: Catchment 201 Catchment UC13 Catchment UC19 Phase 1 Total Phase 2: Catchment 202 Catchment UC15 Catchment UC16 Phase 2 Total Phase 3: Catchment 203	(ha) 0.96 0.05 0.03 1.04 0.50 0.03 0.03 0.05 0.58 0.68 0.03	(m ²) 9600 543 300 10443 5000 300 500 5800 6800 300	C 0.9 0.5 0.5 0.9 0.5 0.5 0.9 0.9 0.5	year storm 1.00 0.63 1.00 0.63 1.00 0.63 1.00 0.63 1.00 0.63 1.00 0.63 0.63 1.00 0.63 0.63	on high-lise residential criteria from City of Mississauga Development Requirements Manual (2.01.01.01) - September 2016	
Phase 1: Catchment 201 Catchment UC13 Catchment UC19 Phase 1 Total Phase 2: Catchment 202 Catchment UC15 Catchment UC16 Phase 2 Total Phase 3: Catchment 203 Catchment UC14	(ha) 0.96 0.05 0.03 1.04 0.50 0.03 0.05 0.58 0.68 0.03 0.71	(m ²) 9600 543 300 10443 5000 300 500 5800 6800 300 7100	C 0.9 0.5 0.5 0.9 0.5 0.5 0.9 0.5	year storm 1.00 0.63 0.63 1.00 0.63 0.63 0.63 0.63 0.63 0.63 0.63 0.63 0.63 1.00 0.63	criteria from City of Mississauga Development Requirements Manual (2.01.01.01) - September 2016	
Phase 1: Catchment 201 Catchment UC13 Catchment UC19 Phase 1 Total Phase 2: Catchment 202 Catchment UC15 Catchment UC16 Phase 2 Total Phase 3: Catchment 203 Catchment UC14 Phase 3 Total Phase 4: Catchment 204	(ha) 0.96 0.05 0.03 1.04 0.50 0.03 0.05 0.58 0.68 0.03 0.71 1.03	(m ²) 9600 543 300 10443 5000 300 500 5800 6800 300 7100 10326	C 0.9 0.5 0.5 0.9 0.5 0.5 0.9 0.5 0.9 0.5 	year storm 1.00 0.63 0.63 1.00 0.63 1.00 0.63 0.63 0.63 0.63 1.00 0.63 1.00 0.63 1.00 0.63	or high-lise residential criteria from City of Mississauga Development Requirements Manual (2.01.01.01) - September 2016	
Phase 1: Catchment 201 Catchment UC13 Catchment UC19 Phase 1 Total Phase 2: Catchment 202 Catchment UC15 Catchment UC16 Phase 2 Total Phase 3: Catchment 203 Catchment UC14 Phase 3 Total Phase 4: Catchment 204	(ha) 0.96 0.05 0.03 1.04 0.50 0.03 0.05 0.58 0.68 0.03 0.71 1.03 0.03	(m ²) 9600 543 300 10443 5000 300 500 5800 6800 300 7100 10326 300	C 0.9 0.5 0.5 0.9 0.5 0.5 0.9 0.5 0.9 0.5	year storm 1.00 0.63 0.63 1.00 0.63 0.63 0.63 0.63 0.63 0.63 1.00 0.63 1.00 0.63	on high-lise residential criteria from City of Mississauga Development Requirements Manual (2.01.01.01) - September 2016	
Phase 1: Catchment 201 Catchment UC13 Catchment UC19 Phase 1 Total Phase 2: Catchment 202 Catchment UC15 Catchment UC16 Phase 3 Total Phase 3 Total Phase 4: Catchment 204 Catchment UC12 Catchment UC12	(ha) 0.96 0.05 0.03 1.04 0.50 0.03 0.05 0.58 0.68 0.03 0.71 1.03 0.03 0.03 0.04	(m ²) 9600 543 300 10443 5000 300 500 5800 6800 300 7100 10326 300 400	C 0.9 0.5 0.5 0.9 0.5 0.5 0.9 0.5 0.9 0.5 0.5	year storm 1.00 0.63 0.63 1.00 0.63 0.63 0.63 0.63 1.00 0.63 1.00 0.63 1.00 0.63 1 0.63	on high-lise residential criteria from City of Mississauga Development Requirements Manual (2.01.01.01) - September 2016	
Phase 1: Catchment 201 Catchment UC13 Catchment UC19 Phase 1 Total Phase 2: Catchment 202 Catchment UC15 Catchment UC16 Phase 2 Total Phase 3: Catchment 203 Catchment UC14 Phase 3 Total Phase 4: Catchment 204 Catchment UC12 Catchment UC12	(ha) 0.96 0.05 0.03 1.04 0.50 0.03 0.05 0.58 0.68 0.03 0.71 1.03 0.03 0.03 0.04 0.07	(m ²) 9600 543 300 10443 5000 300 500 5800 6800 300 7100 10326 300 400 700	C 0.9 0.5 0.5 0.9 0.5 0.9 0.5 0.9 0.5 0.5 0.5 0.5 0.5 0.5 0.5 0.5	year storm 1.00 0.63 0.63 1.00 0.63 0.63 0.63 0.63 0.63 0.63 1.00 0.63 1.00 0.63 1 0.63 0.63	on high-lise residentia criteria from City of Mississauga Development Requirements Manual (2.01.01.01) - September 2016	
Phase 1: Catchment 201 Catchment UC13 Catchment UC19 Phase 1 Total Phase 2: Catchment 202 Catchment UC15 Catchment UC16 Phase 2 Total Phase 3: Catchment 203 Catchment UC14 Phase 3 Total Phase 4: Catchment 204 Catchment UC12 Catchment UC12 Catchment UC18 Phase 4 Total	(ha) 0.96 0.05 0.03 1.04 0.50 0.03 0.05 0.58 0.68 0.03 0.71 1.03 0.03 0.04 0.07 1.17	(m ²) 9600 543 300 10443 5000 300 500 5800 6800 300 7100 10326 300 400 700 11726	C 0.9 0.5 0.5 0.9 0.5 0.9 0.5 0.9 0.5 0.5 0.5 0.5 0.5 0.5 0.5 0.5	year storm 1.00 0.63 0.63 1.00 0.63 0.63 0.63 0.63 0.63 0.63 0.63 1.00 0.63 1 0.63 0.63 0.63 0.63	or high-lise residential criteria from City of Mississauga Development Requirements Manual (2.01.01.01) - September 2016	
Phase 1: Catchment 201 Catchment UC13 Catchment UC19 Phase 1 Total Phase 2: Catchment 202 Catchment UC15 Catchment UC15 Catchment UC16 Phase 3 Total Phase 3: Catchment 203 Catchment UC14 Phase 3 Total Phase 4: Catchment 204 Catchment UC12 Catchment UC17 Catchment UC18 Phase 4 Total	(ha) 0.96 0.05 0.03 1.04 0.50 0.03 0.05 0.58 0.68 0.03 0.71 1.03 0.03 0.04 0.07 1.17 3.51	(m ²) 9600 543 300 10443 5000 300 5800 6800 300 7100 10326 300 400 700 11726 35069	C 0.9 0.5 0.5 0.9 0.5 0.9 0.5 0.9 0.5 0.9 0.5 0.5 0.5 0.9 0.5 -	year storm 1.00 0.63 0.63 1.00 0.63 0.63 0.63 0.63 0.63 0.63 0.63 0.63 0.63 0.63 0.63 1 0.63 0.63 0.63 0.63 0.63	on high-lise residentia criteria from City of Mississauga Development Requirements Manual (2.01.01.01) - September 2016	
Phase 1: Catchment 201 Catchment UC13 Catchment UC19 Phase 1 Total Phase 2: Catchment 202 Catchment UC15 Catchment UC15 Catchment UC16 Phase 3 Total Phase 3: Catchment 203 Catchment UC14 Phase 3 Total Phase 4: Catchment 204 Catchment UC12 Catchment UC12 Catchment UC17 Catchment UC18 Phase 4 Total Total Site	(ha) 0.96 0.05 0.03 1.04 0.50 0.03 0.05 0.58 0.68 0.03 0.71 1.03 0.03 0.07 1.17 3.51	(m ²) 9600 543 300 10443 5000 300 500 5800 6800 300 7100 10326 300 400 700 11726 35069	C 0.9 0.5 0.5 0.9 0.5 0.9 0.5 0.9 0.5 0.9 0.5 0.5 0.5 0.5 0.9 0.5 0.9 0.5 0.9 0.5 -	year storm 1.00 0.63 0.63 1.00 0.63 0.63 0.63 0.63 0.63 1.00 0.63 1.00 0.63 1 0.63 0.63 1 0.63	on high-fise residentia criteria from City of Mississauga Development Requirements Manual (2.01.01.01) - September 2016	
Phase 1: Catchment 201 Catchment UC13 Catchment UC19 Phase 1 Total Phase 2: Catchment 202 Catchment UC15 Catchment UC16 Phase 2 Total Phase 3: Catchment 203 Catchment UC14 Phase 3 Total Phase 4: Catchment 204 Catchment UC12 Catchment UC12 Catchment UC12 Catchment UC13 Phase 4 Total Phase 4 Total Total Site	(ha) 0.96 0.05 0.03 1.04 0.50 0.03 0.05 0.58 0.68 0.03 0.71 1.03 0.03 0.04 0.07 1.17 3.51 y adjusme	(m ²) 9600 543 300 10443 5000 300 500 5800 6800 300 7100 10326 300 400 700 11726 35069 nt factor to	C 0.9 0.5 0.5 0.9 0.5 0.9 0.5 0.9 0.5 0.9 0.5 0.9 0.5 RC as follow	year storm 1.00 0.63 0.63 1.00 0.63 0.63 1.00 0.63 1.00 0.63 1.00 0.63 1.00 0.63 1.00 0.63 1.00 0.63 5	on high-fise residentia criteria from City of Mississauga Development Requirements Manual (2.01.01.01) - September 2016	
Phase 1:Catchment 201Catchment UC13Catchment UC19Phase 1 TotalPhase 2:Catchment 202Catchment UC15Catchment UC16Phase 2 TotalPhase 3:Catchment UC14Phase 3:Catchment UC14Phase 4:Catchment UC12Catchment UC12Catchment UC12Note: For city of Mississauga appl	(ha) 0.96 0.05 0.03 1.04 0.50 0.03 0.05 0.58 0.68 0.03 0.71 1.03 0.03 0.71 1.03 0.03 0.04 0.07 1.17 3.51 y adjusme 10-year	(m ²) 9600 543 300 10443 5000 300 500 5800 6800 300 7100 10326 300 400 700 11726 35069 nt factor to 1.0	C 0.9 0.5 0.5 0.9 0.5 0.9 0.5 0.9 0.5 0.5 0.5 0.5 0.5 0.5 0.5 0.5	year storm 1.00 0.63 0.63 1.00 0.63 0.63 0.63 0.63 0.63 0.63 0.63 0.63 0.63 1 0.63 0.63 0.63 0.63 0.63 0.63 0.63 0.63 0.63	on high-lise residentia criteria from City of Mississauga Development Requirements Manual (2.01.01.01) - September 2016	
Phase 1:Catchment 201Catchment UC13Catchment UC19Phase 1 TotalPhase 2:Catchment 202Catchment UC15Catchment UC15Catchment UC16Phase 2 TotalPhase 3:Catchment 203Catchment UC14Phase 3:Catchment UC14Phase 4:Catchment 204Catchment UC12Catchment UC12Catchment UC13Phase 4:Catchment UC17Catchment UC18Phase 4 TotalTotal SiteNote: For city of Mississauga appl	(ha) 0.96 0.05 0.03 1.04 0.50 0.03 0.05 0.58 0.68 0.03 0.71 1.03 0.03 0.04 0.07 1.17 3.51 y adjusme 10-year 25-year	(m ²) 9600 543 300 10443 5000 300 5800 6800 300 7100 10326 300 7100 10326 300 400 700 11726 35069 nt factor to 1.0 1.1	C 0.9 0.5 0.5 0.9 0.5 0.9 0.5 0.9 0.5 0.5 0.5 0.5 0.5 0.5 0.5 C as follow	year storm 1.00 0.63 0.63 1.00 0.63 0.63 0.63 0.63 1.00 0.63 1 0.63 1 0.63 0.63 1 0.63 1 0.63	on high-lise residentia criteria from City of Mississauga Development Requirements Manual (2.01.01.01) - September 2016	
Phase 1: Catchment 201 Catchment UC13 Catchment UC19 Phase 1 Total Phase 2: Catchment 202 Catchment UC15 Catchment UC15 Catchment UC16 Phase 2 Total Phase 3: Catchment 203 Catchment UC14 Phase 3 Total Phase 4: Catchment 204 Catchment UC12 Catchment UC12 Catchment UC17 Catchment UC18 Phase 4 Total Total Site	(ha) 0.96 0.05 0.03 1.04 0.50 0.03 0.05 0.58 0.68 0.03 0.71 1.03 0.03 0.71 1.03 0.03 0.71 1.03 0.04 0.07 1.17 3.51 y adjusme 10-year 25-year 50-year	(m ²) 9600 543 300 10443 5000 300 500 5800 6800 300 7100 10326 300 7100 10326 300 400 700 11726 35069 nt factor to 1.0 1.1 1.2	C 0.9 0.5 0.5 0.9 0.5 0.5 0.9 0.5 0.9 0.5 0.5 0.5 0.5 RC as follow	year storm 1.00 0.63 0.63 1.00 0.63 0.63 1.00 0.63 1.00 0.63 1.00 0.63 1.00 0.63 5	on high-fise residentia criteria from City of Mississauga Development Requirements Manual (2.01.01.01) - September 2016	



Project: Project No.: 91 Eglinton Avenue East 1525-4876

Revised: 2019-05-31

MODIFIED RATIONAL METHOD - Phase 1 Release rate

MUNICIPALITY: City of Mississauga

Target Control Rate:	0.03	m3/s
	31.56	L/s
Orifice Type:	Tube	
Invert Elevation:	169.23	m
Diameter of Orifice:	75	mm
Area of Orifice (A):	0.0044	sq.m
Orifice Coefficient (Cd):	0.820	
Calculation of Head		
Centroid Elevation:	169.27	m
Water Elevation:	171.60	m
Upstream Head*, (h):	2.33	m
Qa:	(Cd)(A)(2gh)^0.5	

	uu. (uu)	(~)(_gii) 0.0	
Actual Controlled Discharge,	Qa:	0.0245	cms
		24.51	L/s
and to be an a shown and a stift a second so (a a at Vana	Calatra

*Head is based upon orifice area @ orifice face not Vena Contracta



Project: 91 Eglinton Avenue East Project No.: 1525-4876

Date: 2019-05-31 Designed By: NRS Checked By: NC

70

85

100

115

130

145

160

175

190

205

220

235

250

265

280

295

310

325

340

355

370

385

400

415

430

445

50.03

43.39

38.47

34.66

31.62

29.12

27.04

25.26

23.73

22.40

21.22

20.18

19.25

18.41

17.65

16.96

16.32

15.74

15.20

14.71

14.25

13.82

13.42

13.04

12.69

12.36

4200

5100

6000

6900

7800

8700

9600

10500

11400

12300

13200

14100

15000

15900

16800

17700

18600

19500

20400

21300

22200

23100

24000

24900

25800

26700

MODIFIED RATIONAL METHOD - 100-year post to 2-year pre - PHASE 1

MUNICIPALITY: City of Mississauga

JUIFIED	KANONAL	MEINOD .	· 100-)	/eui	posi i	0 z-y	ear	pre -	гпазе

	Target Flow	v Rate				
	С	i (mm/hr)	A (ha)	Q (m3/s)	Q (L/s)	
Phase 1	0.30	59.89	1.04	0.052	52.16	2-year pre-development peak flow
Catchment UC13	0.63	140.69	0.05	0.013	13.27	100-year post-development uncontrolled
Catchment UC19	0.63	140.69	0.03	0.007	7.33	100-year post-development uncontrolled
	Target C	Control Rate f	or Catchment 201	0.032	31.56	
		Actual Co	ntrol Rate (Orifice)	0.025	24.51	
	100-yr Pos	t-Developn	nent Peak Flow			
	С	i (mm/hr)	A (ha)	Q (m3/s)	Qpost(L/s)	
Catchment 201	1.00	140.69	0.96	0.38	375.47	
		Storag	ge Volume Dete	rmination		
	T _d	i	T _d	Q	S _d	
	min	mm/hr	sec	m ³ /s	m³	
	10	176.31	600	0.47	263.95	
	25	102.41	1500	0.27	380.56	
	40	74.58	2400	0.20	437.25	
	55	59.56	3300	0.16	473.11]

0.13

0.12

0.10

0.09

0.08

0.08

0.07

0.07

0.06

0.06

0.06

0.05

0.05

0.05

0.05

0.05

0.04

0.04

0.04

0.04

0.04

0.04

0.04

0.03

0.03

0.03

498.35

517.12 531.52

542.77

551.61

558.57

564.00

568.17

571.28

573.48

574.89

575.61

575.73

575.31

574.40

573.06

571.31

569.21

566.78

564.04

561.03

557.75

554.23

550.48

546.53

542.38

575.73

EQUATIONS:

Intensity $= A/(tc+B)^{C}$

Peak Flow $Q_{pre} = 0.00278 \bullet C_{pre} \bullet i_{(Td)} \bullet A$

REQUIRED STORAGE VOLUME:

Storage $S_d = Q_{post} \bullet T_d - Q_{pre} (T_d + T_c) / 2$

WATER BALANCE

Infiltrate based on 5mm across impervious area 0.78 Impervious Area: ha

Storage Required: 39 m3



Project: Project No.: 91 Eglinton Avenue East 1525-4876

Revised: 2019-05-31

MODIFIED RATIONAL METHOD - Phase 2 Release rate

MUNICIPALITY: City of Mississauga

Target Control Rate:	0.01 9.42	m3/s L/s
Orifice Type: Invert Elevation: Diameter of Orifice: Area of Orifice (A): Orifice Coefficient (Cd):	Plate 169.32 75 0.0044 0.650	m mm sq.m
Calculation of Head Centroid Elevation:	169.36	m
Water Elevation: Upstream Head*, (h):	0.64	m m
Qa:	(Cd)(A)(2gh)^0.	5

	QU.		
Actual Controlled Discharge,	Qa:	0.0102	cms
		10.20	L/s
and the language of the second state of the se			<u> </u>

*Head is based upon orifice area @ orifice face not Vena Contracta



Project: 91 Eglinton Avenue East Project No.: 1525-4876 Date: 2019-05-31 Designed By: NRS Checked By: NC

MODIFIED RATIONAL METHOD - 100-year post to 2-year pre - PHASE 2

MUNICIPALITY: City of Mississauga

	Target Flov	v Rate				_
	С	i (mm/hr)	A (ha)	Q (m3/s)	Q (L/s)	
Phase 2	0.30	59.89	0.58	0.029	28.97	2-year pre-development peak flow
Catchment UC15	0.63	140.69	0.03	0.007	7.33	100-year post-development uncontrolled
Catchment UC16	0.63	140.69	0.05	0.012	12.22	100-year post-development uncontrolled
	Target Control Rate for Catchment 202			0.009	9.42	
	Actual Control Rate (Orifice)			0.010	10.20	-

100-yr Post-Development Peak Flow

	С	i (mm/hr)	A (ha)	Q (m3/s)	Qpost(L/s)
Catchment 202	1.00	140.69	0.50	0.20	195.56

Storage Volume Determination						
T _d	i	T _d	Q	\$ _d		
min	mm/hr	sec	m ³ /s	m³		
10	176.31	600	0.25	139.40		
25	102.41	1500	0.14	202.23		
40	74.58	2400	0.10	233.26		
55	59.56	3300	0.08	253.44		
70	50.03	4200	0.07	268.09		
85	43.39	5100	0.06	279.38		
100	38.47	6000	0.05	288.39		
115	34.66	6900	0.05	295.75		
130	31.62	7800	0.04	301.87		
145	29.12	8700	0.04	307.00		
160	27.04	9600	0.04	311.33		
175	25.26	10500	0.04	315.01		
190	23.73	11400	0.03	318.14		
205	22.40	12300	0.03	320.79		
220	21.22	13200	0.03	323.03		
235	20.18	14100	0.03	324.92		
250	19.25	15000	0.03	326.48		
265	18.41	15900	0.03	327.77		
280	17.65	16800	0.02	328.80		
295	16.96	17700	0.02	329.61		
310	16.32	18600	0.02	330.21		
325	15.74	19500	0.02	330.62		
340	15.20	20400	0.02	330.86		
355	14.71	21300	0.02	330.94		
370	14.25	22200	0.02	330.88		
385	13.82	23100	0.02	330.68		
400	13.42	24000	0.02	330.35		
415	13.04	24900	0.02	329.91		
430	12.69	25800	0.02	329.36		
445	12.36	26700	0.02	328.70		
460	12.05	27600	0.02	327.95		
475	11.75	28500	0.02	327.11		
490	11.47	29400	0.02	326.18		
505	11.21	30300	0.02	325.17		
520	10.96	31200	0.02	324.09		
REQUIRED STORAGE VOLUME: 330.94						

EQUATIONS:

	Intensity I = A/(tc+B)^C	$\frac{\text{Peak Flow}}{\text{Q}_{\text{pre}}} = 0.00278 \bullet \text{C}_{\text{pre}} \bullet \text{i}_{(1)}$		$\frac{\text{Storage}}{S_d = Q_{\text{post}} \bullet T_d - Q_{\text{pre}} (T_d + T_c) / 2$	
		WATER BALAI	NCE		
Infiltrate based on 5mm across impervious area Impervious Area: 0.44 ha					

Storage Required: 22 m3

I:\1500\1525-91 Eglinton Ltd Partnership\4876-91 Eglinton Ave E\Design\Civil_Water\4876_ MRM



Project: Project No.: 91 Eglinton Avenue East 1525-4876

Revised: 2019-05-31

MODIFIED RATIONAL METHOD - Phase 3 Release rate

MUNICIPALITY: City of Mississauga

Target Control Rate:	0.03	m3/s
	20.10	L/ 3
Orifice Type:	Tube	
Invert Elevation:	169.97	m
Diameter of Orifice:	75	mm
Area of Orifice (A):	0.0044	sq.m
Orifice Coefficient (Cd):	0.820	
Calculation of Head		
Centroid Elevation:	170.01	m
Water Elevation:	171.60	m
Upstream Head*, (h):	1.59	m
Qa:	(Cd)(A)(2gh)^0	.5

	au. (cu	.5	
Actual Controlled Discharge,	Qa:	0.0202	cms
		20.25	L/s
and in the second contract a wifting a second of		a a a t Va	

*Head is based upon orifice area @ orifice face not Vena Contracta



Project: 91 Eglinton Avenue East Project No.: 1525-4876

Date: 2019-05-31 Designed By: NRS Checked By: NC

MODIFIED RATIONAL METHOD - 100-year post to 2-year pre - PHASE 3

MUNICIPALITY: City of Mississauga

	Target Flov	v Rate				_
	С	i (mm/hr)	A (ha)	Q (m3/s)	Q (L/s)	
Phase 3	0.30	59.89	0.71	0.035	35.43	2-year pre-development peak flow
Catchment UC14	0.63	140.69	0.03	0.007	7.33	100-year post-development uncontrolled
	Target Control Rate for Catchment 203		0.028	28.10		
	Actual Control Rate (Orifice)			0.020	20.25	-

100-yr Post-Development Peak Flow

	C	i (mm/hr)	A (ha)	Q (m3/s)	Qpost(L/s)
Catchment 203	1.00	140.69	0.68	0.27	265.73

Storage Volume Determination						
T _d	i	T _d	Q	S _d		
min	mm/hr	sec	m ³ /s	m³		
10	176.31	600	0.33	184.62		
25	102.41	1500	0.19	265.84		
40	74.58	2400	0.14	304.65		
55	59.56	3300	0.11	328.72		
70	50.03	4200	0.09	345.27		
85	43.39	5100	0.08	357.25		
100	38.47	6000	0.07	366.14		
115	34.66	6900	0.07	372.79		
130	31.62	7800	0.06	377.74		
145	29.12	8700	0.06	381.36		
160	27.04	9600	0.05	383.89		
175	25.26	10500	0.05	385.54		
190	23.73	11400	0.04	386.43		
205	22.40	12300	0.04	386.68		
220	21.22	13200	0.04	386.37		
235	20.18	14100	0.04	385.57		
250	19.25	15000	0.04	384.35		
265	18.41	15900	0.03	382.74		
280	17.65	16800	0.03	380.79		
295	16.96	17700	0.03	378.53		
310	16.32	18600	0.03	375.99		
325	15.74	19500	0.03	373.20		
340	15.20	20400	0.03	370.17		
355	14.71	21300	0.03	366.92		
	386.68					

EQUATIONS:

<u>Intensity</u> $I = A/(tc+B)^C$ Peak Flow $\overline{Q}_{pre} = 0.00278 \bullet C_{pre} \bullet i_{(Td)} \bullet A$

Storage $S_d = Q_{post} \bullet T_d - Q_{pre} (T_d + T_c) / 2$

WATER BALANCE

Infiltrate based on 5mm across impervious area

Impervious Area: 0.53 ha Storage Required:

27 m3



Project: Project No.: 91 Eglinton Avenue East 1525-4876

Revised: 2019-05-31

MODIFIED RATIONAL METHOD - Phase 4 Release rate

MUNICIPALITY: City of Mississauga

Target Control Rate:	0.02	m3/s
	24.35	L/s
Orifice Type:	Tube	
Invert Elevation:	169.19	m
Diameter of Orifice:	75	mm
Area of Orifice (A):	0.0044	sq.m
Orifice Coefficient (Cd):	0.820	
Calculation of Head		
Centroid Elevation:	169.23	m
Water Elevation:	171.50	m
Upstream Head*, (h):	2.27	m
Qa:	(Cd)(A)(2ab)^0.5	
Area of Orifice (A): Orifice Coefficient (Cd): Calculation of Head Centroid Elevation: Water Elevation: Upstream Head*, (h): Qa:	0.0044 0.820 169.23 171.50 2.27 (Cd)(A)(2gh)^0.5	sq.m m m

	QU.		
Actual Controlled Discharge,	Qa:	0.0242	cms
		24.19	L/s
	~	· · · · · · · · · · · · · · · · · · ·	<u> </u>

*Head is based upon orifice area @ orifice face not Vena Contracta



Project: 91 Eglinton Avenue East Project No.: 1525-4876 Date: 2019-05-31 Designed By: NRS Checked By: NC

MODIFIED RATIONAL METHOD - 100-year post to 2-year pre - PHASE 4

MUNICIPALITY: City of Mississauga

	Target Flov	v Rate			_	
	С	i (mm/hr)	A (ha)	Q (m3/s)	Q (L/s)	
Phase 4	0.30	59.89	1.17	0.059	58.57	2-year pre-development peak flow
Catchment UC12	0.63	140.69	0.03	0.007	7.33	100-year post-development uncontrolled
Catchment UC17	0.63	140.69	0.04	0.010	9.78	100-year post-development uncontrolled
Catchment UC18	0.63	140.69	0.07	0.017	17.11	100-year post-development uncontrolled
	Target Control Rate for Catchment 204			0.024	24.35	
Actual Control Rate (Orifice)			0.024	24.19	-	

100-yr Post-Development Peak Flow						
	С	i (mm/hr)	A (ha)	Q (m3/s)	Qpost(L/s)	
Catchment 204	1.00	140.69	1.03	0.40	403.87	

Storage Volume Determination						
T _d	i	T _d	Q	\$ _d		
min	mm/hr	sec	m ³ /s	m³		
10	176.31	600	0.51	285.53		
25	102.41	1500	0.29	411.95		
40	74.58	2400	0.21	473.90		
55	59.56	3300	0.17	513.44		
70	50.03	4200	0.14	541.57		
85	43.39	5100	0.12	562.74		
100	38.47	6000	0.11	579.21		
115	34.66	6900	0.10	592.28		
130	31.62	7800	0.09	602.77		
145	29.12	8700	0.08	611.23		
160	27.04	9600	0.08	618.05		
175	25.26	10500	0.07	623.51		
190	23.73	11400	0.07	627.83		
205	22.40	12300	0.06	631.17		
220	21.22	13200	0.06	633.67		
235	20.18	14100	0.06	635.42		
250	19.25	15000	0.06	636.53		
265	18.41	15900	0.05	637.05		
280	17.65	16800	0.05	637.05		
295	16.96	17700	0.05	636.58		
310	16.32	18600	0.05	635.68		
325	15.74	19500	0.05	634.40		
340	15.20	20400	0.04	632.76		
355	14.71	21300	0.04	630.79		
370	14.25	22200	0.04	628.52		
385	13.82	23100	0.04	625.97		
400	13.42	24000	0.04	623.17		
415	13.04	24900	0.04	620.11		
430	12.69	25800	0.04	616.84		
445	12.36	26700	0.04	613.35		
	637.05					

EQUATIONS:

<u>Intensity</u> I = A/(tc+B)^C $\frac{\text{Peak Flow}}{\text{Q}_{\text{pre}} = 0.00278 \bullet \text{C}_{\text{pre}} \bullet \text{i}_{(\text{Td})} \bullet \text{A}}$

 $\frac{\text{Storage}}{S_d = Q_{post} \bullet T_d - Q_{pre} (T_d + T_c) / 2$

WATER BALANCE

Infiltrate based on 5mm across impervious area Impervious Area: 0.88 ha Storage Required: 44 m3
Nicole Segal

From:	Kent S Campbell <kent.campbell@forterrabp.com></kent.campbell@forterrabp.com>
Sent:	Friday, July 20, 2018 9:43 AM
То:	Nicole Segal
Cc:	Isabelle Cleroux; Brandon O'Leary
Subject:	RE: 1525-4876 Stormceptor Sizing
Attachments:	Stormceptor Technical Bulletin - Comparative Sizing for ETV & Stormceptor Fine PSDs
	4-23-18.pdf; ISO-14034-Verification-StatementStormceptor_2017-11-10.pdf

Hello Ladies,

It was great talking to you this morning Nicole. I appreciate your patience with my "long winded" Canadian ETV OGS protocol – 60% TSS efficiency vs 80% efficiency for coarser PSD – explanation for Stormceptor EF/EFO sizing. I have attached the Imbrium Tech bulletin I mentioned as well as the Stormceptor EF/EFO ISO verification statement for the Canadian ETV testing program. Thanks too for getting me up to date on your new offices in Bradford and downtown. Please don't hesitate to get back to me if you need the sizing report format we discussed and good luck with your submission.

Have a great weekend,



For the newest version of PCSWMM please visit the Imbrium website at www.imbriumsystems.com

Kent Campbell Stormwater Specialist Cambridge Plant Phone 888-888-3222 **Cell 519 588-7473** kent.campbell@forterrabp.com **Stormceptor Protecting the water for future generations**

From: Isabelle Cleroux [mailto:icleroux@cfcrozier.ca]
Sent: Thursday, July 19, 2018 1:59 PM
To: Kent S Campbell
Cc: Nicole Segal
Subject: 1525-4876 Stormceptor Sizing

Good afternoon Kent,

I am in the process of sizing a Stormceptor for a project but I am having trouble determining which particle size distribution I should be using. The site is in the City of Mississauga and we are looking at a minimum TSS removal of 80%. When trying to use CA ETV as the particle size distribution, the tool does not allow us to use a removal rate of 80%. Would you be able to guide me towards the particle size distribution I need for this site?

Thank you in advance for your help,

| **ISABELLE CLEROUX** | ENGINEERING ASSISTANT | C.F. CROZIER & ASSOCIATES

| 2800 High Point Drive, Suite 100 | Milton, ON L9T 6P4

| cfcrozier.ca | icleroux@cfcrozier.ca | tel 905 875 0026



Land development engineering, from the ground up.

Water Resources • Transportation • Structural • Mechanical • Electrical • Building Science

This communication is intended solely for the attention and use of the named recipients and contains information that is privileged and confidential. If you are not the intended recipient, or the person responsible for delivering this information to the intended recipient, please notify us immediately by telephone. If you have received this information in error, please be notified that you are not authorized to read, copy, distribute, use or retain this message or any part of it.



TECHNICAL BULLETIN

Sizing Stormceptor[®] EF/EFO for Removal of Canadian ETV and Stormceptor Fine Particle Size Distributions

(Issued April 23, 2018)

The Canadian ETV Particle Size Distribution ("ETV PSD", shown in Table 1 below) is reasonably representative of the PSD of particulates found in typical urban stormwater runoff, and was used in sediment removal and scour performance testing of Stormceptor[®] EF/EFO in compliance with the provisions of the Canadian ETV protocol titled *Procedure for Laboratory Testing of Oil-Grit Separators*. Municipalities across Canada are increasingly adopting the sediment removal target of 60% removal of the ETV PSD when sizing an oil-grit separator for pretreatment of stormwater runoff, replacing former sediment removal targets that were based on removal of coarser particle size distributions.

Imbrium Systems supports and recommends adoption of 60% removal of the ETV PSD as a Canada-wide standard for sizing of Stormceptor® EF/EFO. However, it is recognized that in some areas there may continue to be sediment removal targets that are based on removal of coarser particle size distributions. Imbrium engineers have performed extensive sizing analyses to determine the estimated removal efficiency of various coarser PSDs as compared to 60% removal of the ETV PSD. Removal efficiencies were calculated for a wide range of influent flow rates, utilizing Stokes' Law for particle settling and the dimensions and hydraulic capacities of each Stormceptor model size.

Based on these analyses, sizing Stormceptor[®] EF/EFO for 60% removal of the ETV PSD is comparable to sizing for 80% removal of the Stormceptor Fine PSD.



Particle	Percent Less	Particle Size	Dorcont			
Size (µm)	Than	Fraction (µm)	Percent			
1000	100	500-1000	5			
500	95	250-500	5			
250	90	150-250	15			
150	75	100-150	15			
100	60	75-100	10			
75	50	50-75	5			
50	45	20-50	10			
20	35	8-20	15			
8	20	5-8	10			
5	10	2-5	5			
2	5	<2	5			

Table 1:	Particle Size	Distribution o	f Test Sediment
TUDIC I.	i un croic bize	Distribution	i i cococonnent

The particle size distribution shown in Table 1 above is the Canadian ETV Particle Size Distribution ("ETV PSD") specified in the Canadian ETV protocol titled *Procedure for Laboratory Testing of Oil-Grit Separators*.



Project Summary Report: 91 Eglinton - Phase 1 Stormceptor Sizing

	Project Information	& Location				
Project Name	91 Eglinton - Phase 1	Project Number	1525-4876			
City	Mississauga	State/ Province	Ontario			
Country	Canada	Date	6/22/2018			
Designer Information		EOR Information (optional)				
Name	Nicole Segal	Name				
Company	C.F. Crozier and Associates	Company				
Phone #	305-875-0026	Phone #				
Email	nsegal@cfcrozier.ca	Email				

Stormwater Treatment Recommendation

The recommended Stormceptor Model(s) which achieve or exceed the user defined water quality objective for each site within the project are listed in the below Sizing Summary table.

Project Summary													
Site Name	Site NameDrainage Area (ha)Imperviousness %PSDTarget TSS Removal (%)TSS Removal (%) ProvidedReco												
91 Eglinton - Phase 1	linton - 1.04 75.0 CA ETV 60 60 EF6												
			Notes										
Stormceptor per Rainfall and Rur Design estimat removal defined	 Stormceptor performance estimates are based on simulations using PCSWMM for Stormceptor, which uses the EPA Rainfall and Runoff modules. Design estimates listed are only representative of specific project requirements based on total suspended solids (TSS) removal defined by the selected PSD, and based on stable site conditions only, after construction is completed. 												

 For submerged applications or sites specific to spill control, please contact your local Stormceptor representative for further design assistance.



Project Summary Report: 91 Eglinton - Phase 2 Stormceptor Sizing

	Project Information	& Location				
Project Name	91 Eglinton - Phase 2	Project Number	1525-4876			
City	Mississauga	State/ Province	Ontario			
Country	Canada	Date	6/22/2018			
Designer Information		EOR Information (optional)				
Name	Nicole Segal	Name				
Company	C.F. Crozier and Associates	Company				
Phone #	305-875-0026	Phone #				
Email	nsegal@cfcrozier.ca	Email				

Stormwater Treatment Recommendation

The recommended Stormceptor Model(s) which achieve or exceed the user defined water quality objective for each site within the project are listed in the below Sizing Summary table.

Project Summary													
Site Name	NameDrainageImperviousnessPSDTarget TSSTSS RemovalRecordArea (ha)%PSDRemoval (%)(%) ProvidedN												
91 Eglinton - Phase 2	n - 0.58 75.0 CA ETV 60 63 EF6												
			Notes										
 Stormceptor performance estimates are based on simulations using PCSWMM for Stormceptor, which uses the EPA Rainfall and Runoff modules. Design estimates listed are only representative of specific project requirements based on total suspended solids (TSS) removal defined by the selected PSD, and based on stable site conditions only, after construction is completed. 													

 For submerged applications or sites specific to spill control, please contact your local Stormceptor representative for further design assistance.



Project Summary Report: 91 Eglinton - Phase 3 Stormceptor Sizing

	Project Information	a & Location				
Project Name	91 Eglinton - Phase 3	Project Number	1525-4876			
City	Mississauga	State/ Province	Ontario			
Country	Canada	Date	6/22/2018			
Designer Information		EOR Information (optional)				
Name	Nicole Segal	Name				
Company	C.F. Crozier and Associates	Company				
Phone #	305-875-0026	Phone #				
Email	nsegal@cfcrozier.ca	Email				

Stormwater Treatment Recommendation

The recommended Stormceptor Model(s) which achieve or exceed the user defined water quality objective for each site within the project are listed in the below Sizing Summary table.

Project Summary													
Site Name	Site NameDrainage Area (ha)Imperviousness %PSDTarget TSS Removal (%)TSS Removal (%) ProvidedRecommended Mod												
91 Eglinton - Phase 3	0.71 75.0 CA ETV 60 62 EF6												
			Notes										
 Stormceptor performance estimates are based on simulations using PCSWMM for Stormceptor, which uses the EPA Rainfall and Runoff modules. Design estimates listed are only representative of specific project requirements based on total suspended solids (TSS) removal defined by the selected PSD, and based on stable site conditions only, after construction is completed. 													

• For submerged applications or sites specific to spill control, please contact your local Stormceptor representative for further design assistance.



Project Summary Report: 91 Eglinton - Phase 4 Stormceptor Sizing

	Project Information	a & Location				
Project Name	91 Eglinton - Phase 4	Project Number	1525-4876			
City	Mississauga	State/ Province	Ontario			
Country	Canada	Date	6/22/2018			
Designer Information		EOR Information (optional)				
Name	Nicole Segal	Name				
Company	C.F. Crozier and Associates	Company				
Phone #	305-875-0026	Phone #				
Email	nsegal@cfcrozier.ca	Email				

Stormwater Treatment Recommendation

The recommended Stormceptor Model(s) which achieve or exceed the user defined water quality objective for each site within the project are listed in the below Sizing Summary table.

Project Summary												
Site Name	Site NameDrainage Area (ha)Imperviousness %PSDTarget TSS Removal (%)TSS Removal (%) ProvidedRecom M											
91 Eglinton - Phase 4	1.18 75.0 CA ETV 60 63 EF8											
			Notes									
 Stormceptor performance estimates are based on simulations using PCSWMM for Stormceptor, which uses the EPA Rainfall and Runoff modules. Design estimates listed are only representative of specific project requirements based on total suspended solids (TSS) removal defined by the selected PSD, and based on stable site conditions only, after construction is completed. 												

• For submerged applications or sites specific to spill control, please contact your local Stormceptor representative for further design assistance.



CROZIER & ASSOCIATES Consulting Engineers					AL TIME OF	1010 CONCENTR	B ATION (min)	4.6 15.00	91 E STORM 10 YEAR DESIG C	glinton Avenue East & SEWER DESIGN SHE N STORM - CITY OF MISS 0.78	ET ISSAUGA ¹			MAM	ININGS "n	" 0.013		1	PROJECT: PROJECT No.: FILE: DATE: Revised: Design: Updated By: Reviewed By:	91 Eglinton Av 1525-4876 Storm Sewer D June 26, 2018 May 28, 2019 NRS NRS NC	enue East vesign
	FROM	το		RUN-		Cummul.	TIME OF			CONSTANT	ACCUM.	TOTAL			PIPE	VEL.	INITIAL	TIME	ACC. TIME		
STREET	мн	мн	AREA (A)	OFF	AxC	AxC	CONC.	I	Q	CONTROLLED Q	CONSTANT Q	Q	LENGTH	SLOPE	DIA.		Tc	OF CONC	OF CONC.	CAPACITY	% Capacity
			На	COEFF			min	mm/hr	m3/sec	m3/s	m3/s	m3/s	m	%	mm	m/sec	min	min	min	m3/s	
Fut. Armdale Road	PR. MH7 (UC3)	PR. MH8	0.07	0.90	0.06	0.06	15.00	99.2	0.017			0.017	58.9	1.00	300	1.37	15.00	0.72	15.72	0.097	18%
Fut. Armdale Road	203	EX. MH8	0.68	0.90			15.00	99.2		0.020	0.020	0.020									
Fut. Armdale Road	UC14	EX. MH8	0.03	0.50	0.02	0.02	15.00	99.2	0.004			0.024									
Fut. Armdale Road	PR. MH8 (UC2)	EX. MH8	0.06	0.90	0.05	0.13	16.46	93.8	0.034		0.020	0.054	60.8	1.00	300	1.37	15.72	0.74	16.46	0.097	56%
	Total Flow to E	xisting MH 8										0.054									
Fut America Devel			0.00	0.05	0.00	0.00	15.00	00.0	0.000		0.000	0.000									
FUT. Armadie Road		PR. MH6	0.32	0.25	0.08	0.08	15.00	99.2	0.022		0.000	0.022		1.00		1.07	15.00	0.5.4	15.54	0 007	o 197
Fut. Armdale Road	PR. MH/ (UC4)	PR. MH6	0.05	0.90	0.05	0.13	15.00	99.2	0.034		0.000	0.034	44.1	1.00	300	1.37	15.00	0.54	15.54	0.097	36%
		PR. MH5	0.03	0.50	0.02	0.14	15.00	99.2	0.039		0.000	0.039									
Fut Armadala Daad		PR. MH5	0.02	0.50	0.01	0.15	15.00	99.Z	0.041		0.000	0.041	45 4	1.00	275	1.50	15.54	0.49	1/ 01	0 175	2.07
FUI. Affidale koda			0.10	0.90	0.09	0.24	16.01	73.3 00 0	0.064		0.000	0.064	45.4	1.00	3/5	1.37	13.54	0.48	16.01	0.175	36%
			0.03	0.00	0.02	0.20	15.00	77.Z	0.070		0.000	0.070									
Eut Armdala Paad			0.10	0.70	0.07	0.00	12.00	019	0.075		0.000	0.075	10.5	0.50	450	1.07	14 01	0.14	12 10	0 202	E097
TUT. AITTIQUIE KOQQ			0.04	0.70	0.04	0.30	10.10	74.0	0.100		0.000	0.100	12.5	0.50	430	1.27	10.01	0.16	10.10	0.202	30%
			0.05	0.50	0.03	0.41	15.00	77.Z	0.112		0.000	0.112									
Fut Thornwood Drivo			0.04	0.50	0.02	0.43	17.00	77.Z	0.117		0.000	0.117	03.0	0.20	400	0.07	12 10	1.40	1777	0 275	E 707
			0.23	0.70	0.21	0.65	17.77	07.4	0.137		0.000	0.137	75.0	0.20	800	0.77	10.10	1.00	17.77	0.275	57 /6
			0.07	0.50	0.04	0.67	15.00	77.Z	0.104			0.104									
Fut Thorpwood Drivo	201.00		0.03	0.00	0.02	0.00	15.00	77.Z	0.100	0.025	0.025	0.100									
Fut Thornwood Drive	201.00		0.70	0.70			15.00	00.2		0.025	0.025	0.025									
Fut Thornwood Drive	202.00	PR MH2	1.03	0.20			15.00	99 2		0.070	0.059	0.059									
Fut Thornwood Drive	PR MH3 (UC11)	PR MH2	0.18	0.20	0.16	0.85	18.72	86.6	0.203	0.024	0.059	0.262	68.0	0.20	825	1 20	17 77	0.94	18 72	0 642	41%
Fut. Thornwood Drive	PR. MH2	PR. MH1	0.10	0.70	0.00	0.85	18.90	86.1	0.202		0.0.59	0.261	13.0	0.20	825	1.20	18,72	0.18	18.90	0.642	41%
	Total Flow	to PR. MH 1			0.00	0.00			0.202		0.007	0.261		0.20	020			0.10			,.

Notes: 1. A, B, and C coefficients as per City of Mississauga Design Requirements



ST	ORM SEWE	R DESIG	N SHEE	т				Р	ROJECT DET	AILS			DESIGN CRITERIA							
SUM	10 Year St IMIT EGLIN City of	orm (Ultim NTON INC Mississauga	aate) C., T-90 0	04			Pr Des Cho	oject No: Date: Igned by: ecked by:	: 12-029W : 28-Jul-14 : ZS : AH					Min. Diameter = Mannings 'n'= Starting Tc =	300 0.013 15	mm min	Rain	fall Intensity = A = B = C= N	A (Tc+B)^c 1010 4.6 0.78 OMINAL PIPE S	SIZE USED
STREET	FROM MH	то МН	AREA (ha)	RUNOFF COEFFICIENT "R"	'AR'	ACCUM. 'AR'	RAINFALL INTENSITY (mm/hr)	FLOW (m3/s)	CONSTANT CONTROLLED FLOW (m3/s)	ACCUM. CONSTANT FLOW (m3/s)	TOTAL FLOW (m3/s)	LENGTH (m)	SLOPE (%)	PIPE DIAMETER (mm)	FULL FLOW CAPACITY (m3/s)	FULL FLOW VELOCITY (m/s)	INITIAL Tc (mîn)	TIME OF CONCENTRATION (min)	ACC. TIME OF CONCENTRATION (min)	PERCENT FULL (%)
		1			1	I	-						1					<u>,</u>		
Preston Meadow Ave	5	4	0.20	0.60	0.12	0.12	99.2	0.033			0.033	30.0	0.50	375	0.124	1.12	15.00	0.45	15.45	27%
Preston Meadow Ave	4	3	0.53	0.45	0.24	0.36	97.4	0.097			0.097	91.8	0.50	525	0.304	1.40	15.45	1.09	16.53	32%
Kara and Differ				0.00	0.10	0.10	00.0	0.027			0.027	24.4	1.00	200	0.007	1.37	15.00	0.20	15 70	200/
Rencourt Drive	0 0lug	12	0.11	0.90	0.10	0.10	99.2	0.027	0.023	0.023	0.027	24.1	1.00	300	0.097	1.37	15.00	0.29	15.29	26%
טוטנע דט	riug	12	. 0.55	0.00			99.2		0.025	0.025	0.025	0.5	1.00	500	0.057	1.57	15.00	0.10	15,10	
Kencourt Drive	12	3				0.10	98.0	0.026		0.023	0.049	36.0	1.00	300	0.097	1.37	15.29	0.44	15.73	51%
Preston Meadow Ave	3	2	0.47	0.45	0.21	0.67	93.5	0.173		0.023	0.196	87.6	0.50	600	0.434	1.54	16.53	0.95	17.49	45%
	2	1	0.23	0.45	0.10	0.77	90.3	0.193		0.023	0.216	33.3	1.80	600	0.824	2.91	17.49	0.19	17.68	26%
Block 44	Plug	1	0.76	0.60			99.2		0.031	0.031	0.031	12.0	1.00	375	0.175	1.59	15.00	0.13	15.13	18%
						L								(10			17.00	0.35	(7.02	2.40/
Preston Meadow Ave	1	EX. 2	0.25	0.60	0.15	0.92	89.7	0.230		0.054	0.284	43.3	1.80	600	0,824	2.91	17.68	0.25	17.92	34%
Thronwood/Block 48	EX. 1	EX. 2	0.20	0.90	0.18	0.18	99.2	0.051			0.051	17.7	1.19	675	0.917	2.56	15.00	0.12	15.12	6%
Forum Drive	EX. 2	EX. 3	0.13	0.90	0.11	1.22	89.0	0.301		0.054	0.355	40.5	0.99	675	0.836	2.34	17.92	0.29	18.21	42%
Armdale Road	10	7	0.22	0.90	0.20	0.20	99.2	0.054			0.054	67.0	0.50	300	0.068	0.97	15.00	1.15	16.15	79%
Block 46	TEMP. DICB1	7	1.22	0.75			99.2		0.051	0.051	0.051	19.5	1.00	450	0.285	1.79	15.00	0.18	15.18	18%
Armdala Boad	0	0	0.21	0.00	0.27	0.27	00.2	0.076			0.076	20	1.00	200	0.007	1 37	15.00	0.04	15.04	78%
Belbin St /Armdale Road			0.51	0.90	0.27	0.27	99.2	0.070			0.078	46.5	0.50	450	0.097	1.37	15.04	0.61	15.65	68%
beibili oujranidale node		•	0.20	0.50	0120	0.50	55.0	01127			01137		0.50	150						
Existing Plaza	7	11				0.70	94.8	0.183		0.051	0.234	11.5	1.25	525	0.481	2.22	16.15	0.09	16.24	49%
Existing Plaza	11	EX, 9	0.23	0.75	0,17	0.87	94.5	0.227		0.051	0.278	40.8	1.50	525	0.527	2.43	16.24	0.28	16.52	53%
Existing Plaza	EX. 9	EX. 8	0.40	0.75	0.74	0.87	93.6	0.225		0.051	0.276	22.8	0.57	525	0.325	1.50	16.52	0.25	16.//	85%
Existing Plaza	EA. 0 FY 7	EX. 7	0.40	0.75	1 12	2 34	92.7	0.311	<u>}</u> →	0.051	0.302	40.0 87.2	0.74	675	0.320	2.01	17.21	0.72	17.21	90%
LADDING TIDZO			1.51	0.75	1.15	2.57		0.372			0.015	07,2	0.75		0.710			0.72		
Fut Armdale Road	FUT. 2	FUT. 1	0.18	0.90	0.16	0.16	99.2	0.045			0.045	58.9	1.00	300	0.097	1.37	15.00	0.72	15.72	46%
Fut Armdale Road	FUT. 1	8	0.12	0.90	0.11	0.27	99.2	0.076			0.076	61.1	1.00	300	0.097	1.37	15.00	0.74	15.74	78%
H			0.50	0.70	0.07			0.000			0.050					4.37	45.00	0.54	45.54	710/
Fut, Armdale Road		FUL 3 FUT 4	0.50	0.50	0.25	0.25	99.2	0.069			0.069	44.1	1.00	300	0.097	1.37	15.00	0.54	15.54	71%
Fut. Armdale Road	FUT. 4	FUT. 5	0.38	0.66	0.25	0.50	95.1	0.133			0.133	18.1	0.50	450	0.202	1.27	16.09	0.24	16.33	66%
Fut. Thronwood Drive	FUT. 5	FUT. 6	0.26	0.90	0.23	0.74	94.2	0.192			0.192	88.5	0.20	600	0.275	0.97	16.33	1.52	17.85	70%
Fut. Thronwood Drive	<u> </u>	FUT. 6	2.00	0.50	1.00	1.00	307.2	0.853			0.853			. 						
Fut, Thronwood Drive		FUT 7	0.83	0.45	0.37	0.37	307.2	0.319			0.319	86.1	0.20	875	0.647	120	17.85	1,19	19 /14	97%
		101.7	0.51	0.50	0.20	2.37	09.2	766.0			0.392	00.1	0.20	023	0.072	1.20		1.17	17.01	<i>72 1</i> 0
Exsitng Eglinton Ave. E	FUT. 7	EX. 17	0.80	0.75	0.60	2.99	85.7	0.711			0.711	97.7	1.00	900	1.810	2.85	19.04	0.57	19.62	39%
Exsitng Eglinton Ave. E	EX. 17	EX. 18		0.75		2.99	84.1	0.698			0.698	85.0	1.00	900	1.810	2.85	19.62	0.50	20.11	39%
Exsiting Eglinton Ave. E	EX. 18	EX. 6	0.55	0.75	U.41	5.40 5.7/	82.8	0,782		0.051	0.782	56.3	1.00	900	1.810	2.85	20.11	U.33 0.38	<u>20.44</u> 20.83	43% 75%
LAGING LYMINUM AYE, E		LA: 17		U.7.J		5.77	01.2	1.300		0.031	1.557	03.7	1.00	,,,,,	1.010	2.0.2	20177		54103	1010
Note: Runoff from Blacks	44 45 and 46 wi	ill he controlled	to 2 vear	nre-develonme	ont level				1											

Urbantech Consulting, A Division of Leighton-Zec Ltd. 25 Royal Crest Court, Suite 201 Markham, Ontario L3R 9X4 TEL: 905.946.9461 FAX: 905.946.9595 www.urbantech.com

.

APPENDIX D

Region's Water and Wastewater Analysis

PUBLIC WORKS Water and Wastewater Program Planning

91 Eglinton Avenue East – City of Mississauga

Analysis in support of the growth-related water and wastewater servicing plan



91 Eglinton Avenue East – City of Mississauga

Contents

E	xecutiv	Summary	3
1	Intr	oduction and Background	5
	1.1	Background	5
	1.2	Objectives	5
2	Plai	ning Context	6
3	Wa	er Servicing	8
	3.1	Existing Infrastructure	8
	3.2	Planned Water Infrastructure	9
	3.3	Water Design Criteria and Service Levels	9
	3.4	Water Servicing Analysis	0
	3.4	1 Water Demand Requirements1	0
	3.4	2 Storage Requirements1	0
	3.4	3 Servicing Alternatives1	1
	3.5	Preferred Servicing Strategy1	2
4	Wa	tewater Servicing1	4
	4.1	Existing Infrastructure	4
	4.2	Planned Wastewater Infrastructure1	5
	4.3	Wastewater Design Criteria and Service Levels1	5
	4.4	Wastewater Servicing Analysis1	5
	4.4	1 Wastewater Flow Requirement1	6
	4.4	2 Capacity of the Existing Sewers adjacent to 91 Eglinton Avenue East development1	6
	4.4	3 Servicing Alternatives1	8
	4.4	Preferred Alternative Analysis2	3
	4.5	Preferred Servicing Strategy2	6
5	Cor	clusion2	8

List of Tables

Table 1	Proposed Development Residential and Employment Forecasts	6
Table 2	Population Growth Forecast Comparison	7
Table 3	Water Demands for the 91 Eglinton Avenue East Block	10
Table 4	Storage Calculation for the 91 Eglinton Avenue East Block	11
Table 5	Wastewater Flows for the 91 Eglinton Avenue East Development	16
Table 6	Wastewater Flows for the 91 Eglinton Avenue East Development By Lots	16

List of Figures

Figure 1	Proposed development sgu boundary	7
Figure 2	Existing Water Infrastructure in the vicinity of Proposed Development	8
Figure 3	Water Servicing Concept for Proposed Development	11
Figure 4	Preferred Water Servicing Strategy	13
Figure 5	Existing Wastewater Infrastructure in the vicinity of Proposed Development	14
Figure 6	Existing capacity of 450 mm Eglinton Ave. East Sewer	17
Figure 7	Existing capacities of 525 mm and 600 mm Sewers, downstream OF 450 mm Sewer	17
Figure 8	Existing capacities of 250 / 300 / 375 mm Sewers	18
Figure 9	Conceptual Internal Wastewater servicing for the proposed development	19
Figure 10	Wastewater Servicing Alternative A	21
Figure 11	Wastewater Servicing Alternative B	22
Figure 12	Wastewater Servicing Alternative A1	24
Figure 13	Wastewater Servicing Alternative A2, A3 and A4	25
Figure 14	Preferred Wastewater Servicing strategy	27

Executive Summary

The City of Mississauga is proposing to develop the 91 Eglinton Avenue East Block, located on the northeast corner of Eglinton Avenue East and Hurontario Street. A water and wastewater servicing study is required to evaluate the servicing alternatives and develop a servicing strategy which will align with the Region's current Water and Wastewater Master Servicing Plan.

The proposed development is located within the City of Mississauga and is one block south of Nahani Way, one block east of Hurontario Street, west of Forum Drive, and is north of Eglinton Avenue East. The total site area is about 11 acres. The proposed land use within the proposed development area is entirely comprised of residential land use as per the data provided by the developers at the time of this report.

Planning	Water Servicing	Wastewater Servicing		
Key Concepts	Key Concepts	Key Concepts		
 The proposed development is contained completely within a single SGU (M1347). Residential population projections for the proposed development are beyond the Region's future 2041 projections (SGU Scenario 15). Development is proposed in an area where potential intensification can occur around the area. The proposed development consists of 7 residential towers. 	 Water servicing to the development will be provided entirely by Pressure Zone 4. Beckett Sproule, Hanlan, Streetsville and Meadowvale pumping stations provide local Zone 4 water service. Storage to the area will be provided by the Tullamore and West and East Brampton reservoirs. Treatment, pumping and transmission are assumed to be sufficient to service the proposed development based on the total population. Connections to the existing system should be made on future Armdale Rd, future Thornwood Drive and Eglinton Avenue East. No new vertical water infrastructure projects were identified to service the proposed development. 	 Wastewater flows from the area drain south by gravity via the East Trunk System to the G.E. Booth wastewater treatment facility. Treatment is assumed to be sufficient to service the proposed development based on future planned infrastructure. Connections to the existing system should be to the Eglinton Avenue East sewer. No triggers to any pumping stations were identified, as the proposed development is serviceable entirely by gravity. However, there are conveyance capacity limitations to infrastructure downstream of the proposed development and further downstream in the East Trunk Sewer system. 		
Next Steps	Next Steps	Next Steps		
Program Planning will be informed of any changes to the projections.	Final connection points and fire flow requirements will be discussed.	Final connections and sanitary sewer upgrades will be discussed.		

1 Introduction and Background

1.1 Background

The 91 Eglinton Block is located on the northeast corner of Eglinton Avenue East and Hurontario Street in the City of Mississauga. A development application has been made to the City of Mississauga for a total of seven (7) towers of varying number of stories.

The total number of units as provided by the developer is 2800. At the time of this report the entire development is assumed to be residential based on the information provided by the developer.

1.2 Objectives

The purpose of this report is to demonstrate the adequacy of the existing water and wastewater infrastructure as well as the proposed water and wastewater infrastructure to satisfy the servicing needs of the proposed development. The intent is also to present the detailed servicing analysis of the proposed development undertaken as part of this study including:

- Establishing water and wastewater servicing requirements.
- Identifying servicing alternatives, if applicable.
- Evaluating the water and wastewater servicing alternatives, if applicable.
- Recommending a preferred water and wastewater servicing strategy for the development.

Details of the analysis are based on the proposed land use, development size and location and the relationship with any other relevant studies that have been completed within the proposed development area.

2 Planning Context

This proposed development lies within the City of Mississauga, just north of Mississauga City Centre and east of the Hurontario Street corridor. The proposed development is assumed to be completely residential. Details of the proposed development are summarized below.

Building No.	Planning Estimates	Number of	Residential	Employment	Total	
5	Ŭ	Units	Population	Population	Population	
1	Tower 1 and Tower 2 Combined	765	2066	0	2066	
2	Tower 3 and Tower 4 Combined	512	1382	0	1382	
3	Tower 5 and Tower 6 Combined	600	1620	0	1620	
4	Tower 7 and Future	923	2492	0	2492	
	Proposed Development Total	2800	7560	0	7560	
	SGU Estimate (2031)		1790	410	2200	
	SGU Estimate (2041)		2860	500	3360	
	SGU Estimate (Ultimate)		6551	1030	7581	
	Note: SGU's Reference Scenario 15 and Scenario 0 respectively					

TABLE 1 PROPOSED DEVELOPMENT RESIDENTIAL AND EMPLOYMENT FORECASTS

Population and employment forecasts from SGU M1347 were considered in the analysis for comparison purposes. It was assumed that 100% of the proposed development will occupy and occur within the entire SGU M1347, as shown in Figure 1.

91 Eglinton Avenue East – City of Mississauga



FIGURE 1 PROPOSED DEVELOPMENT SGU BOUNDARY

The City's planning forecasts for this area are greater than the Region's planned 2041 and Ultimate growth forecasts (SGU Scenario 15 and Scenario 0 respectively), as shown in Table 2. It is important to keep in mind that the SGU contains the developing Summitview sites and well as developed areas in addition to this proposed development.

TABLE 2 POPULATION GROWTH FORECAST COMPARISON

Scenario / Year	Population Growth	Employment Growth	Total Growth	
2031	1790	410	2200	
2041	2860	500	3360	
Ultimate	6551	1030	7581	
Proposed Development Only	7560	0	7560	
Note: Ultimate growth numbers reference Scenario 0 and 2031-41 numbers reference SGU Scenario 15.				

3 Water Servicing

There is water infrastructure surrounding the proposed development which service existing land uses in the area. The development falls within the service boundary of water pressure Zone 4.

3.1 Existing Infrastructure

The major feed to the area is a 600 mm sub-transmission main on Bristol Road connecting to 400 mm and 300 mm watermains on Hurontario Street. Internal servicing is provided through smaller 300 mm distribution mains on Nahani Way, Preston Meadow Ave and Forum Drive. There is a constructed, but not in use, 300 mm watermain on Eglinton Avenue East from Forum Drive up to the proposed site which is intended to be looped through the future Thornwood Drive extension. The pressure zone changes to Zone 3 south of Eglinton Avenue East and west of Forum Drive.





3.2 Planned Water Infrastructure

Based on the Region's latest population and employment growth projections, the existing trunk infrastructure in the area is sufficient to service 2041 demands and there is allowance for growth beyond the 2041 time frame.

There are no new local infrastructures planned in the vicinity of the proposed development for the near future.

3.3 Water Design Criteria and Service Levels

Demands for the proposed development were calculated using the Region's latest water design criteria. The design criteria are summarized as follows:

- 265 Lpcd for average day water consumption.
- A maximum day peaking factor of 1.8 for residential and 1.4 for employment growth.
- A peak hour factor of 3.0.

Establishing hydraulic performance criteria is required in determining the project requirements to service new growth. Assessing the impact of growth on the existing water distribution system was undertaken following the 2013 Water and Wastewater Master Servicing Plan approach.

A linear water project is triggered or flagged for further analysis if it meets one or more of the following criteria:

- Under maximum day demand scenario pipe velocity exceeds 1.5 m/s;
- Under maximum day demand scenario pressure in the system drops below 40 psi or drops by more than 10 psi, reducing the level of service for existing users;
- Pressure in the system drops below 20 psi under a maximum day plus fire scenario.

The trigger for a pumping station upgrade is based on exceeding the firm capacity of the station feeding the area. Firm capacity of a pumping station is defined as the sum of the all the pump capacities minus the largest pump capacity. The station's firm capacity should be able to handle peak hour demands when distributing flow into the local system.

Water storage requirements for the 91 Eglinton Avenue East Block are calculated in accordance with MOECC Guidelines as follows:

Total Storage Requirements = A + B + C where,

- A = Equalization Storage (25% of maximum day demand of zone)
- B = Fire storage in accordance with the standard of Municipal Fire Protection of the Canada Underwriter's Association (modified from the MOECC criteria)
- C = Emergency Storage (25% of A + B)

3.4 Water Servicing Analysis

The objective of the hydraulic water servicing analysis is to identify alternatives for servicing the development and select a servicing strategy that considers the following key impacts:

- Existing level of service
- Water quality
- Security of supply and system redundancy
- Flexibility of servicing
- Complexity and cost of infrastructure
- Opportunity to support long term servicing of other growth areas

The 91 Eglinton Avenue East Block is situated within the serviceable range of Pressure Zone 4. The pressure zone boundary runs through the south side of Eglinton Avenue East in the vicinity of the development but no boundary change expected in the near future. The area will be serviced from the existing Zone 4 pumping stations with the easterly stations (Beckett Sproule and Hanlan) more influential than the westerly stations (Streetsville and Meadowvale). Tullamore, East Brampton and West Brampton reservoirs will provide the floating storage.

Treatment, pumping and transmission are assumed to be sufficient to service the proposed development based on future planned infrastructure.

3.4.1 Water Demand Requirements

Using the design criteria outlined in Section 3.3, the average day, maximum day and peak hour demands for the proposed development were calculated. These demands are summarized in Table 3.

Demand Scenario	Proposed Development	SGU Estimate (2041)	SGU Estimate (Ultimate)	
Average Day (m3/d)	2003.4	890.4	2009.0	
Maximum Day (m3/d)	3606.1	1549.7	3616.1	
Peak Hour (m3/d)	6010.2	2671.2	6026.9	

TABLE 3 WATER DEMANDS FOR THE 91 EGLINTON AVENUE EAST BLOCK

The proposed development is only a part of the overall SGU and contributes towards total water demand requirements that are beyond even the ultimate demand requirements for the entire SGU, as per the Region's growth forecasts outlined in Table 2.

3.4.2 Storage Requirements

As stated earlier, storage will be provided from Tullamore and East and West Brampton pumping stations. All storage facilities have sufficient available storage capacity to 2031 and beyond. Table 4 shows the required storage for the proposed development. The fireflow of the proposed development was assumed to be 83 L/s (residential only) due to lack of actual fireflow data from the proponent.

It was confirmed that the existing storage in the system is sufficient to meet the additional requirement and no new storage upgrades are required.

TABLE 4 STORAGE CALCULATION FOR THE 91 EGLINTON AVENUE EAST BLOCK

Requirement in m3/d	Proposed Development	SGU Estimate (Ultimate)
Equalization: A (25% MDD)	901.5	904.0
Fire Flow: B	7171.2	7171.2
Emergency: C (25% (A+B)	2018.2	2018.8
Total Storage Requirement	10090.9	10094.0

3.4.3 Servicing Alternatives

Typically, a number of alternative servicing strategies are identified and further evaluated to select the most preferred servicing option. In this case, the area is surrounded by existing and planned future infrastructure. Therefore, only one servicing alternative was identified, as shown in Figure 3. Connections to watermains on Armdale Road, Thornwood Drive (future) and Eglinton Avenue East will provide service to the buildings.





Hydraulic modeling was performed to identify impacts to the existing water distribution system and to assess future infrastructure and potential water service connection points.

It was determined that assumed fire flow for the development can be supported by the existing and proposed watermains in the area.

3.5 Preferred Servicing Strategy

The preferred servicing strategy for the 91 Eglinton Avenue East development will be as follows:

- Tower 1 and Tower 2 (combined 765 units) will be serviced via a single connection from the future 300 mm on Thornwood Drive as there are no watermains fronting Eglinton Avenue East, west of Thornwood Drive.
- Tower 3 and Tower 4 (combined 512 units) will be serviced via a single connection from the future 300 mm on Thornwood Drive.
- Tower 5 and Tower 6 (combined 600 units) will be serviced via a single connection from the 300 mm on Armdale Road.
- Tower 7 and future builds (923 units) will be serviced via connections from the 300 mm on Eglinton Avenue East.

The connection sizes, including fire connections, in all cases should be smaller than the watermain size. Region's internal modeling showed that there is no requirement to extend the existing Eglinton Avenue East 300 mm main west Thornwood Drive to connect with the Zone 4 main on Hurontario Street. However, it is required that the future Thornwood main connects to the existing 300 mm Eglinton Avenue East main to complete looping. Also, the internal looping of watermains by connecting Armdale Road main to Thornwood Drive main is required for the purpose of servicing this new development.

The blue circles in Figure 4 show the recommended connection points along the watermains.

91 Eglinton Avenue East – City of Mississauga



FIGURE 4 PREFERRED WATER SERVICING STRATEGY

4 Wastewater Servicing

There is existing wastewater infrastructure surrounding the proposed development, which services the existing land uses in the area. The area is serviced via the East Trunk (Etobicoke Creek West) system, where flows are ultimately treated at the G.E. Booth wastewater treatment facility.

4.1 Existing Infrastructure

The existing sanitary sewers outlet adjacent to subject site are as follows:

An existing 450 mm sanitary sewer, north of Eglinton Avenue East, heading towards the east is connected to an existing 525 mm diameter sanitary sewer on Tailfeather Crescent which in turn heads south along a creek and conveys flow to the Central Park Way Trunk sewer.

An existing 250 mm sanitary sewer along Sorrento Drive, south of Eglinton Avenue East, conveys flow to the 300 / 375 mm sewer on Ella Avenue. Ella Avenue sewer heads west, crosses Hurontario Street, and drains flows to Upper Cooksville Creek Trunk sewer.

Existing wastewater infrastructure in the vicinity of the proposed development is shown in Figure 5.



FIGURE 5 EXISTING WASTEWATER INFRASTRUCTURE IN THE VICINITY OF PROPOSED DEVELOPMENT

4.2 Planned Wastewater Infrastructure

There are no major planned projects around the development area. A new 450 mm sanitary sewer along Eglinton Avenue East from Sorrento Drive to Tailfeather Crescent was built in 2016. The main purpose of this sewer is to service the future development area north of Eglinton Avenue East.

Based on the Region's latest population and employment projections, the existing and planned infrastructure is sufficient to service 2041 wastewater flows and there is some allowance for growth beyond the 2041 time frame.

4.3 Wastewater Design Criteria and Service Levels

Wastewater flows for the proposed development were calculated using the Region's latest revised wastewater design criteria. The wastewater design criteria are summarized as follows:

- 285 Lpcd for average day wastewater generation rate.
- Peaking factor is based on the Harmon formula.
- Inflow and infiltration allowance is based on 0.26 L/s/ha.

Establishing hydraulic performance criteria is required in determining the project requirements to service new growth. Assessing the impact of growth on the existing wastewater collection system was undertaken following the 2013 Water and Wastewater Servicing Master Plan approach.

A linear wastewater project is triggered or flagged for further analysis if it meets the following criteria:

- Pipe is surcharged and,
- Maximum water level is within 1.8 meters of ground level, indicating the potential for basement flooding,
- Under a 1 in 5 year design storm, Soil Conservation Service (SCS) Type II.

The trigger for a pumping station upgrade is based on exceeding the firm capacity of the station servicing the area. Firm capacity of a pumping station is defined as the sum of all the pump capacities minus the largest pump. The station's firm capacity should be able to handle peak wet weather flows.

4.4 Wastewater Servicing Analysis

The objective of the hydraulic wastewater servicing analysis is to identify alternatives for servicing the development and select a servicing strategy that considers the following key impacts:

- Existing level of service
- System capacity
- Complexity and cost of infrastructure
- Opportunity to support long term servicing of other growth areas

The 91 Eglinton Avenue East development will be serviced by the East Trunk sewer system. The area drains by gravity via the East Trunk system to the G.E. Booth wastewater treatment facility. It was confirmed that treatment capacity is sufficient to service the 91 Eglinton Avenue East development. However, hydraulic modelling shows conveyance capacity limitations to infrastructure adjacent to the proposed development and further downstream in the East Trunk Sewer System.

4.4.1 Wastewater Flow Requirement

The theoretical average dry weather flow, peak dry weather flow and peak wet weather flows were calculated using the design criteria described in Section 4.3. The estimated wastewater flows for this development (91 Eglinton Avenue East) are presented in Table 5.

TABLE 5 WASTEWATER FLOWS FOR THE 91 EGLINTON AVENUE EAST DEVELOPMENT

Flow Scenario	Proposed Development	SGU Estimate (2041)	SGU Estimate (Ultimate)
Average Dry Flow (L/s)	25	3.8	8.7
Peak Dry Flow (L/s)	76.7	14.5	30.4
Peak Wet Weather (L/s)	78	15.5	30.6

Table 6 shows the population split for the new 91 Eglinton Avenue East development by lot.

	Unit	Area-ha	Population	Peak wet weather Flow
Lot 1- Tower A & B	765	0.8	2066	24.6
Lot 2- Tower C & D	512	0.7	1382	17.1
Lot 3- Tower E & F	600	0.8	1620	19.7
Lot 4- Tower G & future	923	0.8	2492	29.1

TABLE 6 WASTEWATER FLOWS FOR THE 91 EGLINTON AVENUE EAST DEVELOPMENT BY LOTS

The proposed development is only a part of the overall SGU (M1347). Hydraulic modeling was performed to determine if the existing collection system has sufficient capacity to convey the higher wastewater flows generated by the additional population.

4.4.2 Capacity of the Existing Sewers adjacent to 91 Eglinton Avenue East development

4.4.2.1 Eglinton Ave. Sewer (450mm)

The existing sanitary sewer, north of Eglinton Avenue East from Sorrento Drive to Tailfeather Crescent is a 450 mm sanitary sewer. This sewer is connected to an existing 525 / 600 mm diameter sanitary sewer on Tailfeather Crescent which is headed south along the creek and conveys flows to the Central Parkway Trunk sewer.

Overall, the minimum slope of the 450 mm diameter sanitary sewer is 0.99%, providing a maximum capacity of approximately 284 L/s. The two sections of 525 mm sewer have minimum slopes of 0.39% and 0.276%, providing a maximum capacity of approximately 269 & 226 L/s respectively. The minimum slope of the 600 mm diameter sanitary sewer is 0.4%, providing a maximum capacity of 390 L/s. Figure 6 and 7 show a plan and profile of the existing 450 mm, 525 mm & 600 mm sewers.

A modelling analysis of the existing wastewater system and 2041 condition was undertaken to determine if there is sufficient conveyance capacity in the existing 450 mm, 525 mm & 600 mm sanitary sewers.

Based on the results of the analysis, the existing 450 mm sewer has enough capacity but linear conveyance upgrades of the 525 mm and 600 mm sanitary sewers will be required to accommodate the proposed development.



FIGURE 6 EXISTING CAPACITY OF 450 MM EGLINTON AVE. EAST SEWER





4.4.2.2 Sorrento Drive Sanitary Sewer (250 / 300 mm)

The existing 250 mm sanitary sewer along Sorrento Drive, south of Eglinton Avenue East conveys flow to the 300 / 375 mm sewer on Ella Avenue. Ella Avenue sewer is headed west, crossing Hurontario Street, and drains to the 825 / 750 mm Upper Cooksville Creek Trunk sewer.

The minimum slope of the 250 mm diameter sanitary sewer is 0.72%, having a maximum capacity of 51 L/s. Some sections of the existing 375 mm sewer between have very low slope (0.183% and 0.242%)

providing a capacity of only 75 L/s. Figure 8 shows a plan and profile of the existing 250 / 300 / 375 mm diameter sanitary sewer on Sorrento Drive and Ella Avenue.

A modelling analysis of the existing wastewater system and 2041 condition was undertaken to determine if there is sufficient conveyance capacity in the existing 250 / 300 / 375 mm sanitary sewer to service the proposed growth.

Based on the results of the analysis, the existing sanitary sewer on Sorrento Drive does not have enough capacity. Also, an upgrade of the 750 / 825 mm Upper Cooksville Creek Trunk sewer will be required for the proposed development.



FIGURE 8 EXISTING CAPACITIES OF 250 / 300 / 375 MM SEWERS

4.4.3 Servicing Alternatives

The sanitary flows from subject site should be conveyed through the proposed 300 mm / 375 mm sewers along Armdale Road and the future Thornwood Drive. The proposed sewers will also provide the possibility of servicing Block 46 (Summitview Eglinton Development), located adjacent to the subject site. Multiple connections are proposed to the Armdale Road and future Thornwood Drive sewers to convey the wastewater flows generated by the proposed development. Figure 9 shows the conceptual wastewater servicing layout for the proposed development.



The approach for wastewater servicing is based on utilizing existing sanitary infrastructure in the vicinity of the proposed development site. Three wastewater servicing alternatives were identified and further evaluated to select the most preferred servicing option.

- Drain the sanitary flows from the proposed development to the existing 450 mm sewer along the north side of Eglinton Avenue East.
- Drain the sanitary flows from the proposed development to the existing 250 mm sewer along Sorrento Drive.
- Split the sanitary flows from the proposed development between the 450 mm Eglinton Avenue sewer and 250 mm Sorrento Drive sewer.

4.4.3.1 Wastewater Servicing Alternative A

The first alternative wastewater servicing concept is shown in Figure 10 and is based on conveying the generated flow to the existing 450 mm sewer on Eglinton Avenue East. The flows would drain to the existing 525 / 600 mm sanitary sewer on Tailfeather Crescent which is headed south along the creek and conveys flows to Central Park Way Trunk sewer, and they will eventually be discharged by gravity via the East Trunk sanitary sewer to the G.E. Booth wastewater treatment facility.

Sanitary Model analysis revealed that the existing 525 mm / 600 mm sewers do not have enough capacity to convey additional flow from this development so, two options can be considered:

- Upsizing approximately 900 m of the existing 525 mm / 600 mm sewer to 675mm. Or,
- Twinning the existing 525 mm / 600 mm sewer by constructing a new 450 mm sewer.

4.4.3.2 Wastewater Servicing Alternative B

The second alternative wastewater servicing concept is shown in Figure 11 and is based on conveying the generated flows through the existing 250 mm sanitary sewer along Sorrento Drive, south of Eglinton Avenue East to the 300 / 375 mm sewer on Ella Avenue. Ella Avenue sewer heads west, crossing Hurontario Street, and drains to the 825 / 750 mm Upper Cooksville Creek Trunk sewer.

Sanitary Model analysis revealed that the existing 250 / 300 /375 mm sewer along Sorrento Drive and Ella Avenue do not have enough capacity to convey additional flow from this development, two options can be considered:

- Upsizing the existing 250 mm / 300 mm / 375 mm sewer on Sorrento Drive and Ella Avenue to 675mm. Or,
- Twinning the existing 250 mm / 300 mm / 375 mm sewer on Sorrento Drive and Ella Avenue by constructing a new 450 mm sewer.

In both options, the sanitary sewers will cross Hurontario Street and convey flows to the existing 825 mm Upper Cooksville Creek trunk sewer. The sanitary model results revealed capacity constraints in some sections of the existing 750 mm / 825 mm Upper Cooksville Trunk sewer, downstream of the possible connection manhole. Therefore, these sections of the Upper Cooksville Creek trunk sewer will require upsizing to 900 mm sewer.

4.4.3.3 Wastewater Servicing Alternative C

This wastewater servicing alternative is based on splitting the generated flow between the existing 450 mm sewer on Eglinton Avenue and 250 mm Sorrento Drive. However, this will mean upsizing the 525 / 600 mm and the 250 / 300 / 375 mm sewers on Tailfeather Crescent and Sorrento Drive respectively. This alternative was not evaluated further due to the amount of upgrades required.

91 Eglinton Avenue East – City of Mississauga





WASTEWATER SERVICING ALTERNATIVE A



FIGURE 11 WASTEWATER SERVICING ALTERNATIVE B

4.4.4 Preferred Alternative Analysis

The preferred wastewater servicing alternative is Alternative A. This alternative utilizes the existing 450 mm sewer on Eglinton Avenue East that will convey flows generated by the new development to the existing 525 mm sewer on Tailfeather Crescent.

However, it is important to note that sanitary model analysis revealed capacity constraints at 525mm / 600 mm sewers, so upsizing the existing sewers or constructing a new sewer is required.

Four options can be considered:

- A1 Upsizing approximately 900 m of the existing 525mm / 600 mm sewer to 675 mm along the Creek and Central Parkway East from manhole number 1795966 to manhole number 1793012. Refer figure 12 for details.
- A2 Constructing a new 450 mm sewer for approximately 900 m along the Creek and Central Parkway East from manhole number 1795966 to manhole number 1793012. Refer figure 13 for details.
- A3 Constructing a new 450 mm sewer for approximately 1300 m along Eglinton Avenue East and Central Parkway East From manhole number 6564041 to manhole number 1793012. Refer figure 13 for details.
- A4 Constructing a new 450 mm sewer for approximately 950 m along Huron Heights Drive, crossing the existing Huron Heights Park through a proposed easement towards Central Parkway to be connected to manhole number 1793012. Refer figure 13 for details.



FIGURE 12 WASTEWATER SERVICING ALTERNATIVE A1

91 Eglinton Avenue East – City of Mississauga



FIGURE 13 WASTEWATER SERVICING ALTERNATIVE A2, A3 AND A4
4.5 Preferred Servicing Strategy

The various options listed in Section 4.4.4 were evaluated using following criteria to determine the preferred servicing strategy.

- Technical feasibility and operational suitability
- Constructability
- Construction cost
- Environmental impact
- Community impact

Comparative assessments of the options were conducted by the Region of Peel wastewater team and alternative A4 was considered as the preferred wastewater servicing strategy.

It is important to note that this preferred strategy would require a dedicated easement along the existing municipal Huron Heights Park. The preferred wastewater servicing strategy is shown in figure 16.

The preferred wastewater servicing strategy can be summarized as follows:

- Install a new 300 mm sewer (approximately 240 m length) along Armdale Road from manhole number 1 to manhole number 3.
- Install a new 375 mm sewer (approximately 180 m length) along the future Thornwood Drive from manhole number 3 to the existing 450 mm sewer.
- Install a new 450 mm sewer (approximately 950 m length) along Huron Heights Drive, crossing an existing park through a proposed easement toward Central Parkway to be connected to manhole number 1793012.





PREFERRED WASTEWATER SERVICING STRATEGY

5 Conclusion

The proposed development is located within the City of Mississauga and is one block south of Nahani Way, one block east of Hurontario Street, west of Forum Drive, and is north of Eglinton Avenue. The total site area is about 11 acres. The development plan includes seven (7) towers contained within one SGU (M1347). Based on the residential and employment population projections proposed by the City, they are beyond the Region's forecasted 2041 (SGU Scenario 15 and Scenario 0) population.

The proposed development has an equivalent population of 7560 from 2800 units. The Region's 2041 forecast for this SGU includes 2860 residents and 500 employees, for a total population of 3360.

The Region's Ultimate (or Buildout) forecast for this SGU is closer to the proposed development projections and includes 6551 residents and 1030 employees, for a total population of 7581.

Hydraulic modeling was performed to determine if the existing water distribution and wastewater collection system have sufficient capacity to distribute and collect the additional water demands and wastewater flows, respectively, generated by the proposed development.

Recommended Water Servicing

Water servicing to the proposed 91 Eglinton Avenue East development will be provided entirely by Pressure Zone 4 in Mississauga. Zone 4 is serviced by Beckett Sproule and Hanlan pumping stations from the east and Streetsville and Meadowvale pumping stations from the west. The proposed development however is mostly influenced by the easterly pumping stations. Storage to the area will be provided by the existing Tullamore and West and East Brampton reservoirs. The major feed to the area is a 600 mm sub-transmission main on Bristol Road connecting to 400 mm and 300 mm watermains on Hurontario Street.

Four (4) buildings are proposed to be serviced from the future 300 mm on Thornwood Drive, two (2) buildings are proposed to be serviced from the 300 mm on Armdale Road and one (1) building from the existing but not yet in service 300 mm on Eglinton Avenue East.

To provide water service to the proposed development, the following water servicing components are recommended:

- A new future watermain on Thornwood Drive should be a 300mm main which connects at either end to the future 300mm on Armdale Road and existing 300mm on Eglinton Avenue East.
- There is no requirement to extend the existing watermain on Eglinton Avenue East to connect to the 400 mm main on Hurontario Street.
- The service connections should be smaller than the watermain size at all locations to maintain the integrity of the Regional water system.

Recommended Wastewater Servicing

Currently there is existing infrastructure in the area that will collect flows from the 91 Eglinton Avenue East development. However, there are some limitations in downstream conveyance capacity that will need to be addressed to support the proposed development.

The recommended wastewater servicing strategy utilizes the existing 450 mm sewer on Eglinton Avenue East to convey flows generated by the new development to the existing 525 mm sewer on Tailfeather Crescent. The proposed seven (7) residential towers could connect at various locations to the future sewers on Armdale Road and Thornwood Drive to carry the sanitary flows to the 450 mm Eglinton Avenue East sewer.

To provide wastewater service to the proposed development, the following wastewater servicing components are recommended:

- Install a new 300 mm sewer (approximately 240 m length) along Armdale Road from manhole number 1 to manhole number 3.
- Install a new 375 mm sewer (approximately 180 m length) along the future Thornwood Drive from manhole number 3 to the existing 450 mm sewer.
- Install a new 450 mm sewer (approximately 950 m length) along Huron Heights Drive, crossing an existing park through a proposed easement toward Central Parkway to be connected to manhole number 1793012.

FIGURES



















	SECTION E SCALE H 1:100 V 1:50	
175.00	5 10 15 20 25 30	35 †175.00
174.50		174.50
174.00		174.00
173.50	PROPOSED STREET LIGHT-	173.50
173.00	PROPOSED TREE	173.00
173.00	PROPOSED VITUTY POLE	175.00
172.50		172.50
172.00		172.00
171.50	171.04 171.25 17	171.50
171.00		- 171.00
170.50		170.50
170.00 S	PROPOSED 3.0m	170.00
₩ 169.50	STREETSCAPE CORRIDOR	- 169.50
169.00	LIMIT OF EXISTING	169.00
168.50	4.50m	168.50
168.00	ExistING 900mmø	168.00
167.50	INV=167.60± 0.50m 0.75m	167.50
167.00	EXISTING 330mm/	167.00
166.50		166.50
166.00		166.00
165.50		165.50
165.00	SANTARY SEWE	165.00
164.50		164.50
164.00		164.00



	1	ISSUED FOR 2nd. SUBMISSION	2019/MAY/31
	No.	ISSUE / REVISION	YYYY/MMM/DD
	ELEV CITY METR	VATION NOTE: 'ATIONS SHOWN HEREON ARE MISSISSAUGA DATUM AND ARE REL OF MISSISSAUGA BENCH MARK No. 1073, HAVING AN ELEVATION IES.	ATED TO THE OF 171.721
	SUR	VEY NOTES:	
	SUR DRA	VEY COMPLETED BY KRCMAR SURVEYORS LTD. (JULY, 22, 2017) WNG NAME: 17-1538T01	
	BEAI SPEC AND MERI DIST COM	INGS SHOWN HEREON ARE GRID BEARINGS DERIVED FROM CPS O JIFED CONTROL POINTS 'A' AND 'B', USING THE LEICA SMARTINET ARE REFERERED TO THE 6' UTIM CO-ORDINATE SYSTEM, ZONE 17, DIAN BYDO' WEST LONGITUDE. (NADB3 (CSRS) (2010)) NACES ARE GROUND AND CAN BE CONVERTED TO GRID BY MULTI SINED SCALE FACTOR OF 0.999759	BSERVATIONS OF RTK NETWORK, CENTRAL PLYING BY THE
	SITE	PLAN NOTES:	
	DESI DRA PRO	GN ELEMENTS ARE BASED ON MASTER PLAN BY DIALOG MING No.: RZ-OIb (2019/JAN/18) IECT No.: N/A	
	DRA	WING NOTES:	
	THIS THE OFFI THE REPO THIS PLAT	DRAWING IS THE EXCLUSIVE PROPERTY OF C.F. CROZER & ASSC REPRODUCTION OF ANY PART OF IT WITHOUT PROR WRITTEN CO ZE IS STRICTLY PROHIBITED. CONTRACTOR SHALL VERIFY ALL DIMENSIONS, LEVELS, AND DATU CONTRACTOR SHALL VERIFY ALL DIMENSIONS TO THIS OFFICE PRIOR TO DRAWING IS TO BE READ AND UNDERSTOOD IN COMJUNCTION WI IS AND DOCUMENTS APPLICABLE TO THIS PROJECT. DO NOT SCAL	CIATES INC. AND NSENT OF THIS MS ON SITE AND CONSTRUCTION. TH ALL OTHER LE THIS DRAWING.
	ALL CON	EXISTING UNDERGROUND UTILITIES TO BE VERIFIED IN THE FIELD I TRACTOR PRIOR TO CONSTRUCTION.	BY THE
		Mississau	lga
	Projec	PROPOSED HIGH-RISE DEVELOPME	INT
	1	91 & 131 EGLINTON AVE. E. AN	D
	1	5055 HURONTARIO ST.	
	Drawin	TIT OF MISSISSAUGA	
	1	FGUNTON AVENUE FAST	
OR CONSTRUCTION		ROAD SECTION (NORTH SI	DE)
Stomp Flow TANTIN S636 S636 S636 S636 S636 S6466 S646 S646 S646 S646 S646 S646 S646 S6	(CROZIER CONSULTING ENGINEERS	0INT DRIVE 00 L9T 6P4 0026 T 4915 F 0ZIER.CA
The local states	Drawn	M.I.M. Design N.S. Project No. 1525	5-4876
	Check	S.C. Check N.C. Scale Dwg.	FIG 4
1	<u> </u>	II	

NOTE: SEE LANDSCAPE DESIGN DRAWINGS, DETAILS AND SPECIFICATIONS FOR STREETSCAPE INSTALLATION. (ie. TREES, SIDEWALK ETC.)





	1	ISSUED FOR 2nd SUBMISSION	2019 /MAY /31
	No		
	ELE	VATION NOTE:	
	ELEV CITY MET	/ATIONS SHOWN HEREON ARE MISSISSAUGA DATUM AND ARE REL/ OF MISSISSAUGA BENCH MARK No. 1073, HAVING AN ELEVATION RES.	ATED TO THE OF 171.721
	SUR	VEY NOTES:	
	SUR DRA	VEY COMPLETED BY KRCMAR SURVEYORS LTD. (JULY, 22, 2017) WING NAME: 17-153BT01	
	BEA SPECAND MER DIST COM	RNOS SHOWN HEREON ARE ORD BEARINGS DERIVED FROM OFE O OFED CONTROL FONTS A' AND B' USING THE LICA SWARTHET ARE REFERRED TO THE 6' UTN CC-ORDINATE SYSTEM, ZOXE 17 DIAN BYOU WEST LONGITUDE. (MADB3 (CSRS) (ZO10)) ANCES ARE GROUND AND CAN BE CONVERTED TO GRID BY MULT BINDE SCALE FACTOR OF 0.999799	BSERVATIONS OF RTK NETWORK, CENTRAL PLYING BY THE
	SITE	PLAN NOTES:	
	DESI DRA PRO	GN ELEMENTS ARE BASED ON MASTER PLAN BY DIALOG WING No.: RZ-01b (2019/JAN/18) JECT No.: N/A	
	DRA	WING NOTES:	
	THIS THE OFFI THE REP THIS PLAI ALL CON	DRAWING IS THE EXCLUSIVE PROPERTY OF C.F. CROZER & ASS REPRODUCTION OF ANY PART OF 11 WHIOLT PROFENSIONE CE IS STROTTLY PROHIBITED. DRAWING STROTTLY PROHIBITED. DRAWING IS TO BE READ AND UNDERSTOOD IN CONJUNCTION WI IS AND DOCUMENTIAL PROFENSION TO THIS OFFICE PRIOR TO IS AND DOCUMENTS APPLICABLE TO THIS PROJECT DO NOT SCA EXISTING UNDERGROUND UTILITIES TO BE VERIFIED IN THE FIELD ITACOTOR PRIOR TO CONSTITUCTION.	DCIATES INC. AND NSENT OF THIS MS ON SITE AND D CONSTRUCTION. TH ALL OTHER LE THIS DRAWING. BY THE
		Mississau	lga
	Projec	YPOPOSED HIGH-RISE DEVELOPME 91 & 131 EGLINTON AVE. E. AN 5055 HURONTARIO ST. CITY OF MISSISSAUGA	ENT ID
NOT FOR CONSTRUCTION	Drawin	EAST PROPERTY LINE AN THORNWOOD DRIVE SECTIO	D NS
	(CONSULTING ENGINEERS	OINT DRIVE 00 L9T 6P4 0026 T 4915 F 0ZIER.CA
	Drawn	M.I.M. Design N.S. Project No. 1525	5-4876
THE OF OT	Check	S.C. Check N.C. Scale Dwg.	FIG 5
		S.C. N.C.	FIG 5

NOTE: SEE LANDSCAPE DESIGN DRAWINGS, DETAILS AND SPECIFICATIONS FOR STREETSCAPE INSTALLATION. (ie. TREES, SIDEWALK ETC.)





	DRAWING NOTES:
	THIS DRAWING IS THE EXCLUSIVE PROPERTY OF C.F. CROZIER & ASSOCIATES INC. AND THE REPRODUCTION OF ANY PART OF IT WITHOUT PRIOR WRITTEN CONSENT OF THIS OFFICE IS STRUCTLY PROHIBITED.
	THE CONTRACTOR SHALL VERIFY ALL DIMENSIONS, LEVELS, AND DATUMS ON SITE AND REPORT ANY DISCREPANCIES OR OMISSIONS TO THIS OFFICE PRIOR TO CONSTRUCTION.
	THIS DRAWING IS TO BE READ AND UNDERSTOOD IN CONJUNCTION WITH ALL OTHER PLANS AND DOCUMENTS APPLICABLE TO THIS PROJECT. DO NOT SCALE THIS DRAWING.
	ALL EXISTING UNDERGROUND UTILITIES TO BE VERIFIED IN THE FIELD BY THE CONTRACTOR PRIOR TO CONSTRUCTION.
	MISSISSAUGA
0	Project PROPOSED HIGH-RISE DEVELOPMENT
	5055 HURONTARIO ST.
EX. STM	CITY OF MISSISSAUGA
MH19	
FOR CONSTRUCTION	PRE-DEVELOPMENT DRAINAGE PLAN
Stamp	CROZIER CONSULTING ENGINEERS 2800 High Point Drive Suite 100 Milton, ON LGT 6P4 905-875-0026 T 905-875-0026 T 905-875-0026 T 905-875-0026 T 905-875-0026 T
	Drawn M.I.M. Design N.S. Project No. 1525-4876
	Check S.C. Check N.C. Scale 1:500 Dwg. FIG 6

SURVEY NOTES:



_		
1	ISSUED FOR 2nd. SUBMISSION	2019/MAY/31
No.	ISSUE / REVISION	YYYY/MMM/DD
ELE CIT ME	EVATION NOTE: VATIONS SHOWN HEREON ARE MISSISSAUGA DATUM AND ARE RELA OF MISSISSAUGA BENCH MARK No. 1073, HAVING AN ELEVATION IRES.	NTED TO THE OF 171.721

SURVEY COMPLETED BY KROWAR SURVEYORS LTD. (JULY, 22, 2017) DRAWNG NAME: 17-1538T01 BEARINGS SHOWN HERECON ARE GRID BEARINGS DERVED FROM GPS OBSERVATIONS OF BEARINGS SHOWN HERECON ARE GRID BEARINGS DERVED FROM GPS OBSERVATIONS OF MERIDAN BY TO THE G UTIM CO-ORDINASE STEM, ZONE 17, CENTRAL MERIDAN BYTOW MEST LONGTINE (MADB (CARS) (2010))

DISTANCES ARE GROUND AND CAN BE CONVERTED TO GRID BY MULTIPLYING BY THE COMBINED SCALE FACTOR OF 0.999759

SITE PLAN NOTES: DESIGN LELVENTS ARE BASED ON MASTER PLAN BY DIALOG DRAWING No: RZ-OID (2019/JAN/18) PROJECT No: N/A

habitan haa mar yayahar hart	EGUNTON AVE. E.
144	KEY PLAN Scale: N.T.S.
	LEGEND
	PROPERTY LINE
	EXISTING CONTOUR (0.5m)
	EXISTING CONTOUR (1.0m)
	EXISTING DITCH
× 215.00	EXISTING GRADE
	EXISTING OVERLAND FLOW DIRECTION
-	EXISTING STORM DRAINAGE CATCHMENT
	CATCHMENT I.D.
ARC	AREA (ha) RUNOFF COEFFICIENT

-SITE LOCATION

1/



