

August 26, 2019

VIA E-MAIL TO: [BruceMR@gsai.ca](mailto:BruceMR@gsai.ca)

**Bruce McCall-Richmond, MCIP, RPP**  
**Glenn Schnarr & Associates Inc.**  
 700 – 10 Kingsbridge Garden Circle  
 Mississauga, Ontario  
 L5R 3K6

**Re: Addendum Letter, Proposed Residential Development, Wealthy Place, City of Mississauga, Ontario**

As requested, we are providing this addendum letter to update the sound level predictions based on the latest site plan last revised August 20, 2019 included in Figure A. Our latest noise report for this site is entitled, “Noise Feasibility Study, Proposed Residential Development, Wealthy Place, City of Mississauga, Ontario” dated October 16, 2018. Table 1 below includes the updated sound levels.

**Table 1: Predicted Sound Levels, Without Mitigation, [dBA]**


Prediction Location	Description	Daytime – in OLA LEQ-16 hr	Daytime – at the Façade LEQ-16 hr	Nighttime – at the Façade LEQ-8 hr
[A]	Lot 1, proposed 2 ½ storey dwelling	63	66	64
[B]	Lot 2, proposed 2 ½ storey dwelling	<55	57	53
[C]	Lot 8, proposed 2 ½ storey dwelling	61	64	62
[D]	Lot 7, proposed 2 ½ storey dwelling	<55	57	53
[E]	Lot 9, proposed 2 ½ storey dwelling	61	65	62

Based on the updated predicted sound levels, the acoustic barrier, ventilation requirements and building façade constructions included in our previous report dated October 16, 2018 are still applicable. Figure B attached includes the barrier and ventilation requirements.


We trust this information is sufficient for your purposes. If you have any questions or concerns, please call.

Yours truly,

**HOWE GASTMEIER CHAPNIK LIMITED**

  
 Victor Garcia, P.Eng



  
 Sheeba Paul, MEng, P.Eng



